

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 16 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Κυριακή, 16 Αυγούστου 2026	00:00	45,70	1	1	1	1	1	1			1	1		4
	01:00	42,79	1	1	1	1	1	1			1	1		
	02:00	40,83	1	1	1	1	1	1			1	1		
	03:00	39,65	1	1	1	1	1	1			1	1		
	04:00	38,48	1	1	1	1	1	1			1	1		
	05:00	38,37	1	1	1	1	1	1			1	1		
	06:00	39,54	1	1	1	1	1	1			1	1		
	07:00	42,69	1	1	1	1	1	1			1	1		3
	08:00	46,53	1	1	1	1	1	1			1	1		8
	09:00	49,69	1	1	1	1		1			1	1		13
	10:00	52,12	1	1	1	1		1			1	1		15
	11:00	52,88	1	1	1	1	1	1			1	1		16
	12:00	54,05	1	1	1	1	1	1			1	1		16
	13:00	55,23	1	1	1	1	1	1			1	1		16
	14:00	55,17	1	1	1	1	1	1			1	1		17
	15:00	54,17	1	1	1		1	1			1	1		18
	16:00	53,81	1	1	1		1	1			1	1		18
	17:00	52,52	1	1	1		1	1			1	1		19
	18:00	54,45	1	1	1		1	1			1	1		19
	19:00	54,85	1	1	1		1	1			1	1		19
	20:00	54,93	1	1	1		1	1			1	1		19
	21:00	54,95	1	1	1		1	1			1	1		19
	22:00	52,34	1	1	1		1	1			1	1		17
	23:00	48,66	1	1	1		1	1			1	1		13

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης