

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 17 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Δευτέρα, 17 Αυγούστου 2026	00:00	45,00	1	1	1		1	1			1	1		9
	01:00	41,74	1	1	1		1	1			1	1		5
	02:00	39,50	1	1	1		1	1			1	1		3
	03:00	38,48	1	1	1		1	1			1	1		
	04:00	38,15	1	1	1		1	1			1	1		
	05:00	37,89	1	1	1		1	1			1	1		
	06:00	39,00	1	1	1		1	1			1	1	1	
	07:00	43,33	1	1	1		1	1			1	1	2	6
	08:00	48,06	1	1	1		1	1			1	1		10
	09:00	51,53	1	1	1		1	1			1	1		13
	10:00	54,17	1	1	1		1	1			1	1		16
	11:00	54,58	1	1	1		1	1			1	1		17
	12:00	55,29	1	1	1		1	1			1	1		17
	13:00	56,35	1	1	1		1	1			1	1		19
	14:00	56,81	1	1	1	1	1	1			1	1		19
	15:00	55,32	1	1	1	1	1	1			1	1		19
	16:00	54,85	1	1	1	1	1	1			1	1		18
	17:00	54,88	1	1	1	1	1	1			1	1		18
	18:00	56,10	1	1	1	1	1	1			1	1		18
	19:00	55,73	1		1	1	1	1			1	1		20
	20:00	56,39	1		1	1	1	1			1	1		20
	21:00	55,48	1		1	1	1	1			1	1		20
	22:00	52,44	1		1	1	1	1			1	1		19
	23:00	49,07	1		1	1	1	1			1	1		14

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης