

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 23 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	νοικ. H/ (x20)
Κυριακή, 23 Αυγούστου 2026	00:00	50,01	1	1	1	1	1	1			1	1	1	7
	01:00	46,64	1	1	1	1	1	1			1	1	2	
	02:00	43,30	1	1	1	1	1	1			1	1		
	03:00	41,43	1	1	1	1	1	1			1	1		
	04:00	40,26	1	1	1	1	1	1			1	1		
	05:00	39,65	1	1	1	1	1	1			1	1		
	06:00	40,37	1	1	1	1	1	1			1	1		
	07:00	44,17	1	1	1	1	1	1			1	1	1	1
	08:00	49,15	1	1	1	1	1	1			1	1	1	8
	09:00	53,34	1	1	1	1	1	1			1	1	1	10
	10:00	56,32	1	1	1	1	1	1			1	1		13
	11:00	57,99	1	1	1	1	1	1			1	1		15
	12:00	60,28	1	1	1	1	1	1			1	1		17
	13:00	62,40	1	1	1	1	1	1			1	1		19
	14:00	62,79	1	1	1	1	1	1			1	1		20
	15:00	61,91	1	1	1	1	1	1			1	1		20
	16:00	61,48	1	1	1	1	1	1			1	1		20
	17:00	61,69	1	1	1	1	1	1			1	1		20
	18:00	61,89	1	1	1	1	1	1			1	1		20
	19:00	59,89	1	1	1	1	1	1			1	1		20
	20:00	60,52	1	1	1	1	1	1			1	1		20
	21:00	60,57	1	1	1	1	1	1			1	1		20
	22:00	57,96	1	1	1	1	1	1			1	1		18
	23:00	54,32	1	1	1	1	1	1			1	1		14

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης