

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 24 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Δευτέρα, 24 Αυγούστου 2026	00:00	49,92	1	1	1	1	1	1			1	1	1	8
	01:00	46,83	1	1	1	1	1	1			1	1	2	
	02:00	44,46	1	1	1	1	1	1			1	1		
	03:00	42,54	1	1	1	1	1	1			1	1		
	04:00	41,75	1	1	1	1	1	1			1	1		
	05:00	41,61	1	1	1	1	1	1			1	1		
	06:00	42,30	1	1	1	1	1	1			1	1		
	07:00	46,23	1	1	1	1	1	1			1	1		3
	08:00	51,98	1	1	1	1	1	1			1	1		9
	09:00	56,26	1	1	1	1	1	1			1	1		13
	10:00	58,72	1	1	1	1	1	1			1	1		16
	11:00	60,24	1	1	1	1	1	1			1	1		18
	12:00	62,39	1	1	1	1	1	1			1	1		19
	13:00	64,04	1	1	1	1	1	1			1	1		20
	14:00	63,75	1	1	1	1	1	1			1	1		20
	15:00	62,98	1	1	1	1	1	1			1	1		20
	16:00	62,44	1	1	1	1	1	1			1	1		20
	17:00	62,40	1	1	1	1	1	1			1	1		20
	18:00	62,50	1	1	1	1	1	1			1	1		20
	19:00	60,30	1	1	1	1	1	1			1	1		20
	20:00	60,19	1	1	1	1	1	1			1	1		20
	21:00	59,60	1	1	1	1	1	1			1	1		20
	22:00	57,26	1	1	1	1	1	1			1	1		17
	23:00	53,28	1	1	1	1	1	1			1	1		13

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης