

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 25 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	νοικ. H/ (x20)
Τρίτη, 25 Αυγούστου 2026	00:00	49,21	1	1	1	1	1	1			1	1	1	7
	01:00	46,10	1	1	1	1	1	1			1	1	1	
	02:00	43,56	1	1	1	1	1	1			1	1		
	03:00	41,64	1	1	1	1	1	1			1	1		
	04:00	40,84	1	1	1	1	1	1			1	1		
	05:00	41,45	1	1	1	1	1	1			1	1		
	06:00	42,41	1	1	1	1	1	1			1	1		
	07:00	46,84	1	1	1	1	1	1			1	1	2	1
	08:00	52,54	1	1		1	1	1			1	1	2	10
	09:00	56,21	1	1		1	1	1			1	1		16
	10:00	59,35	1	1		1	1	1			1	1		18
	11:00	60,20	1	1		1	1	1	1		1	1		14
	12:00	62,76	1	1		1	1	1	1		1	1		15
	13:00	64,54	1	1		1	1	1	1		1	1		17
	14:00	64,68	1	1		1	1	1	1		1	1		18
	15:00	64,06	1	1		1	1	1	1		1	1		18
	16:00	63,39	1	1		1	1	1	1		1	1		18
	17:00	62,64	1	1		1	1	1	1		1	1		18
	18:00	63,04	1	1		1	1	1	1		1	1		18
	19:00	61,34	1	1		1	1	1	1		1	1		18
	20:00	61,32	1	1		1	1	1	1		1	1		18
	21:00	60,64	1	1		1	1	1	1		1	1		18
	22:00	58,14	1	1		1	1	1	1		1	1		15
	23:00	54,60	1	1		1	1	1	1		1	1		12

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης