

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 27 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	νοικ. H/Ζ (x20)
Πέμπτη, 27 Αυγούστου 2026	00:00	50,34	1	1		1	1	1	1		1	1	1	6
	01:00	47,03	1			1	1	1	1		1	1	1	7
	02:00	43,97	1			1	1	1	1		1	1		5
	03:00	42,75	1			1	1	1	1		1	1		5
	04:00	42,89	1			1	1	1	1		1	1		5
	05:00	42,69	1			1	1	1	1		1	1		5
	06:00	43,11	1			1	1	1	1		1	1		5
	07:00	46,83	1			1	1	1	1		1	1		5
	08:00	52,77	1			1	1	1	1		1	1		10
	09:00	57,15	1			1	1	1	1		1	1		15
	10:00	60,14	1		1	1	1	1		1	1		19	
	11:00	61,95	1		1	1	1	1		1	1		19	
	12:00	63,89	1		1	1	1	1		1	1		19	
	13:00	65,32	1		1	1	1	1		1	1		20	
	14:00	65,02	1		1	1	1	1		1	1		20	
	15:00	64,47	1	1	1	1	1	1		1	1		20	
	16:00	64,35	1	1	1	1	1	1		1	1		20	
	17:00	64,52	1	1	1	1	1	1		1	1		20	
	18:00	64,57	1	1	1	1	1	1		1	1		20	
	19:00	63,20	1	1	1	1	1	1		1	1		20	
	20:00	61,76	1	1	1	1	1	1		1	1		20	
	21:00	61,28	1	1		1	1	1		1	1		19	
	22:00	59,11	1	1		1	1	1		1	1		17	
	23:00	55,07	1	1		1	1	1		1	1		13	

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης