

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 30 Ιουλίου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Πέμπτη, 30 Ιουλίου 2026	00:00	47,84			1	1	1	1	1	1		1		13
	01:00	44,25			1	1	1	1	1	1		1		8
	02:00	42,47			1	1	1	1	1	1		1		8
	03:00	40,89			1	1	1	1	1	1		1		8
	04:00	39,85			1	1	1	1	1	1		1		8
	05:00	39,40			1	1	1	1	1	1		1		8
	06:00	40,61			1	1	1	1	1	1		1		8
	07:00	44,90			1	1	1	1	1	1		1		10
	08:00	49,06			1	1	1	1	1	1		1		15
	09:00	52,71			1	1	1	1	1	1		1		18
	10:00	55,43			1	1	1	1	1	1		1		20
	11:00	55,91			1	1	1	1	1	1		1		20
	12:00	57,34			1	1	1	1	1	1		1		20
	13:00	58,00			1	1	1	1	1	1		1	1	20
	14:00	58,10			1	1	1	1	1	1		1	2	20
	15:00	56,81			1	1	1	1	1	1		1	2	20
	16:00	56,18			1	1	1	1	1	1		1	1	20
	17:00	56,29			1	1	1	1	1	1		1	1	20
	18:00	57,46			1	1	1	1	1	1		1	1	20
	19:00	57,70			1	1	1	1	1	1		1	2	20
	20:00	57,01			1	1	1	1	1	1		1	2	20
	21:00	57,21			1	1	1	1	1	1		1	2	20
	22:00	55,59			1	1	1	1	1	1		1	1	20
	23:00	51,56			1	1	1	1	1	1		1		17

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης