

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τετάρτη, 12 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Τετάρτη, 12 Αυγούστου 2026	00:00	49,86	1	1	1	1	1	1	1		1	1		4
	01:00	45,64	1	1	1	1	1	1	1		1	1		1
	02:00	43,68	1	1	1	1	1	1	1		1	1		
	03:00	41,99	1	1	1	1	1	1	1		1	1		
	04:00	40,85	1	1	1	1	1	1	1		1	1		
	05:00	40,46	1	1	1	1	1	1	1		1	1		
	06:00	41,96	1	1	1	1	1	1	1		1	1		
	07:00	46,62	1	1	1	1	1	1	1		1	1		
	08:00	51,55	1	1	1	1	1	1	1		1	1		4
	09:00	54,86	1	1	1	1	1	1	1		1	1		9
	10:00	59,35	1	1	1	1	1	1			1	1		17
	11:00	60,54	1	1	1	1	1	1			1	1		19
	12:00	62,22	1	1	1	1	1	1			1	1		19
	13:00	63,78	1	1	1	1	1	1			1	1		20
	14:00	64,54	1	1	1	1	1	1			1	1		20
	15:00	63,85	1	1	1	1	1	1			1	1		20
	16:00	62,54	1	1	1	1	1	1			1	1		20
	17:00	62,69	1	1	1	1	1	1			1	1		20
	18:00	63,01	1	1	1	1	1	1			1	1		20
	19:00	61,65	1	1	1	1	1	1			1	1		20
	20:00	61,35	1	1	1	1	1	1			1	1		20
	21:00	60,88	1	1	1	1	1	1			1	1		19
	22:00	58,78	1	1	1	1	1	1			1	1		18
	23:00	54,83	1	1	1	1	1	1			1	1		14

Μερική διακοπή στις 09:48 λόγω βλάβης του Α/Σ29. Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης