

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ			Πέμπτη, 20 Αυγούστου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 20 Αυγούστου 2026	00:00	246				1	1	1	
	01:00	227				1	1	1	
	02:00	214				1	1	1	
	03:00	207				1	1	1	
	04:00	202				1	1	1	
	05:00	200				1	1	1	
	06:00	200				1	1	1	
	07:00	204				1	1	1	
	08:00	220				1	1	1	
	09:00	239				1	1	1	
	10:00	252				1	1	1	
	11:00	264				1	1	1	
	12:00	272				1	1	1	
	13:00	265				1	1	1	
	14:00	266				1	1	1	
	15:00	266				1	1	1	
	16:00	261				1	1	1	
	17:00	273				1	1	1	
	18:00	268				1	1	1	
	19:00	290				1	1	1	
	20:00	295				1	1	1	
	21:00	293				1	1	1	
	22:00	290				1	1	1	
	23:00	268				1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ			Παρασκευή, 21 Αυγούστου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 21 Αυγούστου 2026	00:00	248				1	1	1	
	01:00	223				1	1	1	
	02:00	209				1	1	1	
	03:00	197				1	1	1	
	04:00	195				1	1	1	
	05:00	196				1	1	1	
	06:00	198				1	1	1	
	07:00	202				1	1	1	
	08:00	215				1	1	1	
	09:00	236				1	1	1	
	10:00	256				1	1	1	
	11:00	271				1	1	1	
	12:00	286				1	1	1	
	13:00	300				1	1	1	
	14:00	303				1	1	1	
	15:00	295				1	1	1	
	16:00	286				1	1	1	
	17:00	287				1	1	1	
	18:00	291				1	1	1	
	19:00	302				1	1	1	
	20:00	308				1	1	1	
	21:00	310				1	1	1	
	22:00	299				1	1	1	
	23:00	270				1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ			Σάββατο, 22 Αυγούστου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 22 Αυγούστου 2026	00:00	242				1	1	1	
	01:00	221				1	1	1	
	02:00	206				1	1	1	
	03:00	196				1	1	1	
	04:00	192				1	1	1	
	05:00	192				1	1	1	
	06:00	195				1	1	1	
	07:00	202				1	1	1	
	08:00	217				1	1	1	
	09:00	238				1	1	1	
	10:00	257				1	1	1	
	11:00	272				1	1	1	
	12:00	287				1	1	1	
	13:00	305				1	1	1	
	14:00	318				1	1	1	
	15:00	321				1	1	1	
	16:00	319				1	1	1	
	17:00	317				1	1	1	
	18:00	319				1	1	1	
	19:00	320				1	1	1	
	20:00	324				1	1	1	
	21:00	316				1	1	1	
	22:00	299				1	1	1	
	23:00	267				1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ			Κυριακή, 23 Αυγούστου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 23 Αυγούστου 2026	00:00	245				1	1	1	
	01:00	230				1	1	1	
	02:00	216				1	1	1	
	03:00	204				1	1	1	
	04:00	196				1	1	1	
	05:00	192				1	1	1	
	06:00	194				1	1	1	
	07:00	204				1	1	1	
	08:00	222				1	1	1	
	09:00	245				1	1	1	
	10:00	265				1	1	1	
	11:00	280				1	1	1	
	12:00	296				1	1	1	
	13:00	311				1	1	1	
	14:00	323				1	1	1	
	15:00	326				1	1	1	
	16:00	320				1	1	1	
	17:00	315				1	1	1	
	18:00	310				1	1	1	
	19:00	310				1	1	1	
	20:00	313				1	1	1	
	21:00	305				1	1	1	
	22:00	288				1	1	1	
	23:00	264				1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ			Δευτέρα, 24 Αυγούστου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 24 Αυγούστου 2026	00:00	242				1	1	1	
	01:00	221				1	1	1	
	02:00	207				1	1	1	
	03:00	196				1	1	1	
	04:00	190				1	1	1	
	05:00	186				1	1	1	
	06:00	186				1	1	1	
	07:00	195				1	1	1	
	08:00	214				1	1	1	
	09:00	236				1	1	1	
	10:00	256				1	1	1	
	11:00	269				1	1	1	
	12:00	284				1	1	1	
	13:00	301				1	1	1	
	14:00	309				1	1	1	
	15:00	309				1	1	1	
	16:00	296				1	1	1	
	17:00	293				1	1	1	
	18:00	294				1	1	1	
	19:00	302				1	1	1	
	20:00	312				1	1	1	
	21:00	309				1	1	1	
	22:00	294				1	1	1	
	23:00	269				1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ			Τρίτη, 25 Αυγούστου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 25 Αυγούστου 2026	00:00	245				1	1	1	
	01:00	221				1	1	1	
	02:00	204				1	1	1	
	03:00	193				1	1	1	
	04:00	188				1	1	1	
	05:00	187				1	1	1	
	06:00	191				1	1	1	
	07:00	201				1	1	1	
	08:00	222				1	1	1	
	09:00	244				1	1	1	
	10:00	263				1	1	1	
	11:00	272				1	1	1	
	12:00	291				1	1	1	
	13:00	310				1	1	1	
	14:00	317				1	1	1	
	15:00	314				1	1	1	
	16:00	307				1	1	1	
	17:00	308				1	1	1	
	18:00	315				1	1	1	
	19:00	327				1	1	1	
	20:00	329				1	1	1	
	21:00	316				1	1	1	
	22:00	299				1	1	1	
	23:00	270				1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ			Τετάρτη, 26 Αυγούστου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 26 Αυγούστου 2026	00:00	252				1	1	1	
	01:00	232				1	1	1	
	02:00	218				1	1	1	
	03:00	206				1	1	1	
	04:00	198				1	1	1	
	05:00	194				1	1	1	
	06:00	193				1	1	1	
	07:00	202				1	1	1	
	08:00	224				1	1	1	
	09:00	244				1	1	1	
	10:00	260				1	1	1	
	11:00	276				1	1	1	
	12:00	291				1	1	1	
	13:00	298				1	1	1	
	14:00	298				1	1	1	
	15:00	293				1	1	1	
	16:00	286				1	1	1	
	17:00	284				1	1	1	
	18:00	291				1	1	1	
	19:00	308				1	1	1	
	20:00	326				1	1	1	
	21:00	330				1	1	1	
	22:00	312				1	1	1	
	23:00	282				1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης