

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 19 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ρ Α Ξ Ι Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τετάρτη, 19 Αυγούστου 2026	00:00	2,953	1	1						1		2
	01:00	2,695		1						1	1	2
	02:00	2,432		1						1	1	1
	03:00	2,287		1						1	1	1
	04:00	2,208		1							1	1
	05:00	2,142		1							1	1
	06:00	2,208		1							1	1
	07:00	2,267		1							1	1
	08:00	2,553	1	1							1	1
	09:00	2,879	1	1							1	1
	10:00	3,143	1	1							1	1
	11:00	3,309	1	1						1	1	1
	12:00	3,395	1	1						1	1	1
	13:00	3,505	1	1						1	1	1
	14:00	3,490	1	1						1	1	1
	15:00	3,519	1	1						1	1	1
	16:00	3,525	1	1						1	1	1
	17:00	3,575	1	1						1		2
	18:00	3,782	1	1						1		2
	19:00	3,863	1	1						1		2
	20:00	4,022	1	1						1		2
	21:00	4,050	1	1						1		2
	22:00	3,666	1	1						1		2
	23:00	3,388	1	1						1		2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 20 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ρ Α Σ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Πέμπτη, 20 Αυγούστου 2026	00:00	3,093	1	1						1		2
	01:00	2,820	1	1						1		2
	02:00	2,562	1	1						1		1
	03:00	2,416	1	1						1		1
	04:00	2,310	1	1								1
	05:00	2,265	1	1								1
	06:00	2,333	1	1								1
	07:00	2,386	1	1								1
	08:00	2,632	1	1						1		1
	09:00	2,936	1	1						1		1
	10:00	3,192	1	1					1	1		1
	11:00	3,301	1	1					1	1		1
	12:00	3,448	1	1					1	1		1
	13:00	3,616	1	1					1	1		1
	14:00	3,660	1	1					1	1		1
	15:00	3,527	1	1					1	1		1
	16:00	3,494	1	1					1	1		1
	17:00	3,556	1	1					1	1		2
	18:00	3,710	1	1					1			2
	19:00	3,963	1	1					1			2
	20:00	4,064	1	1					1			2
	21:00	3,910	1	1					1			2
	22:00	3,658	1	1					1			2
	23:00	3,367	1	1					1			2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 21 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ρ Α Σ Κ Ε Υ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Παρασκευή, 21 Αυγούστου 2026	00:00	3,215	1	1					1			2
	01:00	3,035	1	1					1			2
	02:00	2,845	1	1					1			1
	03:00	2,620	1	1					1			1
	04:00	2,522	1	1					1			1
	05:00	2,452	1	1					1			1
	06:00	2,451	1	1								1
	07:00	2,504	1	1								1
	08:00	2,794	1	1					1			1
	09:00	2,943	1	1					1			1
	10:00	3,211	1	1					1	1		1
	11:00	3,296	1	1					1	1		1
	12:00	3,380	1	1					1	1		1
	13:00	3,502	1	1					1	1		1
	14:00	3,528	1	1					1	1		1
	15:00	3,519	1	1					1	1		1
	16:00	3,608	1	1					1	1		1
	17:00	3,656	1	1					1			2
	18:00	3,754	1	1					1			2
	19:00	3,813	1	1					1			2
	20:00	3,989	1	1					1			2
	21:00	3,913	1	1					1			2
	22:00	3,671	1	1					1			2
	23:00	3,420	1	1					1			2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 22 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ρ Α Κ Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Σάββατο, 22 Αυγούστου 2026	00:00	3,228	1	1					1			2
	01:00	3,059	1	1					1			2
	02:00	2,836	1	1					1			1
	03:00	2,673	1	1					1			1
	04:00	2,547	1	1					1			1
	05:00	2,482	1	1					1			1
	06:00	2,509	1	1					1			1
	07:00	2,570	1	1					1			1
	08:00	2,817	1	1					1			1
	09:00	3,052	1	1					1	1		1
	10:00	3,266	1	1					1	1		1
	11:00	3,400	1	1					1	1		1
	12:00	3,532	1	1					1	1		1
	13:00	3,656	1	1					1	1		1
	14:00	3,784	1	1					1	1		1
	15:00	3,712	1	1					1	1		1
	16:00	3,778	1	1					1	1		1
	17:00	3,815	1	1					1			2
	18:00	3,986	1	1					1			2
	19:00	4,134	1	1					1	1		2
	20:00	4,257	1	1					1	1		2
	21:00	4,176	1	1					1	1		2
	22:00	3,849	1	1					1	1		2
	23:00	3,591	1	1					1	1		2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 23 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ε Π Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Κυριακή, 23 Αυγούστου 2026	00:00	3,386	1	1					1			2
	01:00	3,178	1	1					1			2
	02:00	2,956	1	1					1			1
	03:00	2,755	1	1					1			1
	04:00	2,644	1	1					1			1
	05:00	2,534	1	1					1			1
	06:00	2,589	1	1					1	1		1
	07:00	2,608	1	1					1	1		
	08:00	2,832	1	1					1	1		
	09:00	3,084	1	1					1	1		1
	10:00	3,302	1	1					1	1		1
	11:00	3,438	1	1					1	1		1
	12:00	3,553	1	1					1	1		1
	13:00	3,620	1	1					1	1		1
	14:00	3,660	1	1					1	1		1
	15:00	3,720	1	1					1	1		1
	16:00	3,732	1	1					1	1		1
	17:00	3,745	1	1					1	1		2
	18:00	3,797	1	1					1			2
	19:00	3,796	1	1					1			2
	20:00	3,999	1	1					1			2
	21:00	3,998	1	1					1			2
	22:00	3,817	1	1					1			2
	23:00	3,641	1	1					1			2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 24 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ρ Α Κ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Δευτέρα, 24 Αυγούστου 2026	00:00	3,512	1	1					1			2
	01:00	3,377	1	1					1			2
	02:00	3,181	1	1					1			1
	03:00	2,993	1	1					1			1
	04:00	2,844	1	1					1			1
	05:00	2,730	1	1					1			1
	06:00	2,742	1	1					1			1
	07:00	2,745	1	1					1			1
	08:00	2,902	1	1					1			1
	09:00	3,064	1	1					1			1
	10:00	3,195	1	1					1	1		1
	11:00	3,273	1	1					1	1		1
	12:00	3,360	1	1					1	1		1
	13:00	3,472	1	1					1	1		1
	14:00	3,519	1	1					1	1		1
	15:00	3,530	1	1					1	1		1
	16:00	3,501	1	1					1	1		1
	17:00	3,622	1	1					1			2
	18:00	3,710	1	1					1			2
	19:00	3,690	1	1					1			2
	20:00	3,810	1	1					1			2
	21:00	3,725	1	1					1			2
	22:00	3,599	1	1					1			2
	23:00	3,434	1	1					1			2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 25 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ε Π Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τρίτη, 25 Αυγούστου 2026	00:00	3,262	1	1					1	1		2
	01:00	3,050	1						1	1		2
	02:00	2,824	1						1	1		1
	03:00	2,621	1						1	1		1
	04:00	2,544	1						1	1		1
	05:00	2,477	1						1	1		1
	06:00	2,543	1						1			1
	07:00	2,556	1						1			1
	08:00	2,786	1						1		1	1
	09:00	2,921	1						1		1	1
	10:00	3,176	1						1	1	1	1
	11:00	3,261	1						1	1	1	1
	12:00	3,380	1						1	1	1	1
	13:00	3,476	1						1	1	1	1
	14:00	3,496	1						1	1	1	1
	15:00	3,482	1						1	1	1	1
	16:00	3,536	1						1	1	1	1
	17:00	3,505	1	1					1			2
	18:00	3,566	1	1					1			2
	19:00	3,575	1	1					1			2
	20:00	3,670	1	1					1			2
	21:00	3,650	1	1					1			2
	22:00	3,442	1	1					1			2
	23:00	3,247	1	1					1			2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση