

ΗΣ ΚΥΘΝΟΥ		Προτεινόμενος ΗΕΠ				Πέμπτη, 6 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Πέμπτη, 6 Αυγούστου 2026	00:00	2,679	1	1					1			1
	01:00	2,448	1	1					1			1
	02:00	2,290	1	1								1
	03:00	2,192	1	1								1
	04:00	2,133	1	1								1
	05:00	2,093	1	1								1
	06:00	2,083	1	1								1
	07:00	2,117	1	1								1
	08:00	2,211	1	1								1
	09:00	2,398	1	1					1			1
	10:00	2,615	1	1					1			1
	11:00	2,760	1	1					1			1
	12:00	2,794	1	1					1			1
	13:00	2,831	1	1					1			1
	14:00	2,881	1	1					1			1
	15:00	2,936	1	1					1			1
	16:00	3,011	1	1					1			1
	17:00	3,061	1	1					1			1
	18:00	3,257	1	1					1			2
	19:00	3,387	1	1					1			2
	20:00	3,354	1	1					1			2
	21:00	3,350	1	1					1			2
	22:00	3,097	1	1								2
	23:00	2,867	1	1								2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Προτεινόμενος ΗΕΠ				Παρασκευή, 7 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ρ Ε Σ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Παρασκευή, 7 Αυγούστου 2026	00:00	2,743	1	1								2
	01:00	2,553	1	1								2
	02:00	2,393	1	1								2
	03:00	2,276	1	1								1
	04:00	2,210	1	1								1
	05:00	2,168	1	1								1
	06:00	2,161	1	1								1
	07:00	2,202	1	1								1
	08:00	2,314	1	1								1
	09:00	2,502	1	1								2
	10:00	2,718	1	1								2
	11:00	2,866	1	1								2
	12:00	2,918	1	1								2
	13:00	2,960	1	1								2
	14:00	3,010	1	1								2
	15:00	3,079	1	1								2
	16:00	3,154	1	1								2
	17:00	3,211	1	1						1		2
	18:00	3,423	1	1						1		2
	19:00	3,577	1	1						1		2
	20:00	3,461	1	1						1		2
	21:00	3,397	1	1						1		2
	22:00	3,152	1	1								2
	23:00	2,967	1	1								2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Προτεινόμενος ΗΕΠ				Σάββατο, 8 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ρ Ε Σ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Σάββατο, 8 Αυγούστου 2026	00:00	2,824	1	1								2
	01:00	2,727	1	1								2
	02:00	2,603	1	1								2
	03:00	2,471	1	1								2
	04:00	2,360	1	1								2
	05:00	2,303	1	1								1
	06:00	2,289	1	1								1
	07:00	2,361	1	1								2
	08:00	2,444	1	1								2
	09:00	2,612	1	1								2
	10:00	2,800	1	1								2
	11:00	2,946	1	1								2
	12:00	3,036	1	1								2
	13:00	3,107	1	1								2
	14:00	3,144	1	1					1			2
	15:00	3,190	1	1					1			2
	16:00	3,239	1	1					1			2
	17:00	3,287	1	1					1			2
	18:00	3,468	1	1					1			2
	19:00	3,609	1	1					1			2
	20:00	3,538	1	1					1			2
	21:00	3,467	1	1					1			2
	22:00	3,191	1	1					1			2
	23:00	3,046	1	1								2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Προτεινόμενος ΗΕΠ				Κυριακή, 9 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ρ Ε Σ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Κυριακή, 9 Αυγούστου 2026	00:00	2,972	1	1								2
	01:00	2,896	1	1								2
	02:00	2,770	1	1								2
	03:00	2,636	1	1								2
	04:00	2,513	1	1								2
	05:00	2,406	1	1								2
	06:00	2,344	1	1								2
	07:00	2,317	1	1								2
	08:00	2,366	1	1								2
	09:00	2,471	1	1								2
	10:00	2,640	1	1								2
	11:00	2,803	1	1								2
	12:00	2,929	1	1								2
	13:00	3,020	1	1								2
	14:00	3,100	1	1								2
	15:00	3,150	1	1					1			2
	16:00	3,219	1	1					1			2
	17:00	3,309	1	1					1			2
	18:00	3,482	1	1					1			2
	19:00	3,617	1	1					1			2
	20:00	3,610	1	1					1			2
	21:00	3,568	1	1					1			2
	22:00	3,330	1	1					1			2
	23:00	3,184	1	1					1			2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Προτεινόμενος ΗΕΠ				Δευτέρα, 10 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Δευτέρα, 10 Αυγούστου 2026	00:00	3,155	1	1					1			2
	01:00	2,958	1	1								2
	02:00	2,755	1	1								2
	03:00	2,581	1	1								2
	04:00	2,434	1	1								2
	05:00	2,324	1	1								1
	06:00	2,297	1	1								1
	07:00	2,332	1	1								1
	08:00	2,431	1	1								2
	09:00	2,584	1	1								2
	10:00	2,722	1	1								2
	11:00	2,858	1	1								2
	12:00	2,927	1	1								2
	13:00	2,971	1	1								2
	14:00	3,002	1	1								2
	15:00	2,985	1	1								2
	16:00	2,982	1	1								2
	17:00	2,966	1	1								2
	18:00	3,101	1	1								2
	19:00	3,287	1	1					1			2
	20:00	3,357	1	1					1			2
	21:00	3,457	1	1					1			2
	22:00	3,291	1	1					1			2
	23:00	3,211	1	1					1			2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Προτεινόμενος ΗΕΠ				Τρίτη, 11 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τρίτη, 11 Αυγούστου 2026	00:00	3,102	1	1					1			2
	01:00	2,853	1	1								2
	02:00	2,635	1	1								2
	03:00	2,467	1	1								2
	04:00	2,344	1	1								1
	05:00	2,263	1	1								1
	06:00	2,229	1	1								1
	07:00	2,250	1	1							1	1
	08:00	2,344	1	1							1	1
	09:00	2,519	1	1							1	1
	10:00	2,698	1	1							1	1
	11:00	2,853	1	1							1	1
	12:00	2,895	1	1							1	1
	13:00	2,907	1	1							1	1
	14:00	2,939	1	1							1	1
	15:00	2,954	1	1							1	1
	16:00	3,008	1	1							1	1
	17:00	3,034	1	1							1	1
	18:00	3,190	1	1							1	2
	19:00	3,386	1	1							1	2
	20:00	3,443	1	1							1	2
	21:00	3,450	1	1							1	2
	22:00	3,259	1	1							1	2
	23:00	3,097	1	1							1	2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Προτεινόμενος ΗΕΠ				Τετάρτη, 12 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τετάρτη, 12 Αυγούστου 2026	00:00	2,916	1	1								2
	01:00	2,698	1	1								2
	02:00	2,494	1	1								2
	03:00	2,330	1	1						1		1
	04:00	2,219	1	1						1		1
	05:00	2,162	1	1								1
	06:00	2,148	1	1								1
	07:00	2,164	1	1								1
	08:00	2,291	1	1								1
	09:00	2,443	1	1								2
	10:00	2,648	1	1								2
	11:00	2,842	1	1								2
	12:00	2,897	1	1								2
	13:00	2,914	1	1								2
	14:00	2,947	1	1								2
	15:00	2,971	1	1								2
	16:00	3,048	1	1								2
	17:00	3,104	1	1								2
	18:00	3,322	1	1						1		2
	19:00	3,563	1	1						1		2
	20:00	3,452	1	1						1		2
	21:00	3,453	1	1						1		2
	22:00	3,344	1	1						1		2
	23:00	3,167	1	1						1		2

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση