

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 5 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Τετάρτη, 5 Αυγούστου 2026	00:00	2,280		1			1	1		1
	01:00	2,138		1			1	1		
	02:00	2,013		1			1	1		
	03:00	1,880		1			1	1		
	04:00	1,773		1			1	1		
	05:00	1,735		1			1	1		
	06:00	1,729		1			1	1		
	07:00	1,848		1			1	1		
	08:00	2,031		1			1	1		
	09:00	2,288		1				1		1
	10:00	2,398		1				1		1
	11:00	2,463		1			1	1		1
	12:00	2,470		1			1	1		1
	13:00	2,457		1			1	1		1
	14:00	2,509		1			1	1		1
	15:00	2,450		1			1	1		1
	16:00	2,437		1			1	1		1
	17:00	2,594		1			1	1		1
	18:00	2,769		1			1	1		1
	19:00	2,898		1			1	1		1
	20:00	2,997		1			1	1		1
	21:00	2,998		1			1	1		1
	22:00	2,808		1			1	1		1
	23:00	2,630		1			1	1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 6 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Πέμπτη, 6 Αυγούστου 2026	00:00	2,415		1			1	1		1
	01:00	2,249		1			1	1		
	02:00	2,142		1	1			1		
	03:00	2,046		1	1			1		
	04:00	1,935		1	1			1		
	05:00	1,862		1	1			1		
	06:00	1,812		1	1			1		
	07:00	1,938		1	1			1		
	08:00	2,077		1	1			1		
	09:00	2,271		1	1			1		1
	10:00	2,395		1	1			1		1
	11:00	2,451		1	1			1		1
	12:00	2,502		1	1			1		1
	13:00	2,501		1	1			1		1
	14:00	2,491		1	1			1		1
	15:00	2,432		1	1			1		1
	16:00	2,486		1	1			1		1
	17:00	2,611		1	1			1		1
	18:00	2,806		1	1			1		1
	19:00	2,982		1	1			1		1
	20:00	2,992		1	1			1		1
	21:00	3,010		1	1			1		1
	22:00	2,816		1	1			1		1
	23:00	2,649		1	1			1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Παρασκευή, 7 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Παρασκευή, 7 Αυγούστου 2026	00:00	2,461		1	1		1	1		1
	01:00	2,336		1	1		1	1		
	02:00	2,209		1	1		1	1		
	03:00	2,095		1	1		1	1		
	04:00	1,985		1	1		1	1		
	05:00	1,951		1	1			1		
	06:00	1,934		1	1			1		
	07:00	2,042		1	1			1		
	08:00	2,197		1	1			1		
	09:00	2,400		1	1			1		1
	10:00	2,532		1	1			1		1
	11:00	2,547		1	1			1		1
	12:00	2,628		1	1			1		1
	13:00	2,645		1	1			1		1
	14:00	2,686		1	1			1		1
	15:00	2,637		1	1			1		1
	16:00	2,647		1	1			1		1
	17:00	2,703		1	1			1		1
	18:00	2,863		1	1			1		1
	19:00	3,079		1	1			1		1
	20:00	3,132		1	1			1		1
	21:00	3,140		1	1			1		1
	22:00	2,905		1	1			1		1
	23:00	2,818		1	1			1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 8 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Σάββατο, 8 Αυγούστου 2026	00:00	2,591		1	1		1	1		
	01:00	2,407		1	1		1	1		
	02:00	2,288		1	1		1	1		
	03:00	2,191		1	1		1	1		
	04:00	2,091		1	1		1	1		
	05:00	2,024		1	1			1		
	06:00	2,008		1	1			1		
	07:00	2,146		1	1			1		
	08:00	2,332		1	1			1		1
	09:00	2,488		1	1			1		1
	10:00	2,674		1	1			1		1
	11:00	2,696		1	1			1		1
	12:00	2,723		1	1			1		1
	13:00	2,826		1	1			1		1
	14:00	2,845		1	1			1		1
	15:00	2,794		1	1			1		1
	16:00	2,882		1	1			1		1
	17:00	2,923		1	1			1		1
	18:00	3,043		1	1			1		1
	19:00	3,327		1	1		1	1		1
	20:00	3,360		1	1		1	1		1
	21:00	3,344		1	1		1	1		1
	22:00	3,219		1	1		1	1		1
	23:00	3,098		1	1		1	1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 9 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)		0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000	
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Κυριακή, 9 Αυγούστου 2026	00:00	2,941		1	1		1	1		
	01:00	2,777		1	1		1	1		
	02:00	2,625		1	1		1	1		
	03:00	2,503		1	1		1	1		
	04:00	2,376		1	1		1	1		
	05:00	2,283		1	1		1	1		
	06:00	2,209		1	1			1		
	07:00	2,286		1	1			1		1
	08:00	2,388		1	1			1		1
	09:00	2,525			1		1	1		1
	10:00	2,677			1		1	1		1
	11:00	2,820			1		1	1		1
	12:00	2,792			1		1	1		1
	13:00	2,808			1		1	1		1
	14:00	2,866			1		1	1		1
	15:00	2,820			1		1	1		1
	16:00	2,814			1		1	1		1
	17:00	2,833			1		1	1		1
	18:00	2,974			1		1	1		1
	19:00	3,135			1		1	1		1
	20:00	3,191		1	1		1	1		1
	21:00	3,096		1	1		1	1		1
	22:00	2,997		1	1		1	1		1
	23:00	2,820		1	1		1	1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 10 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Δευτέρα, 10 Αυγούστου 2026	00:00	2,582		1	1		1	1		
	01:00	2,385		1	1		1	1		
	02:00	2,248		1	1			1		
	03:00	2,115		1	1			1		
	04:00	1,985		1	1			1		
	05:00	1,902		1	1			1		
	06:00	1,867		1	1			1		
	07:00	2,004		1	1			1		
	08:00	2,156		1	1			1		
	09:00	2,308		1	1			1		1
	10:00	2,443		1	1			1		1
	11:00	2,471		1	1			1		1
	12:00	2,518		1	1			1		1
	13:00	2,483		1	1			1		1
	14:00	2,540		1	1			1		1
	15:00	2,471		1	1			1		1
	16:00	2,529		1	1			1		1
	17:00	2,655		1	1			1		1
	18:00	2,823		1	1			1		1
	19:00	2,980		1	1			1		1
	20:00	3,034		1	1			1		1
	21:00	3,087		1	1			1		1
	22:00	2,912		1	1			1		1
	23:00	2,716		1	1			1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 11 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Τρίτη, 11 Αυγούστου 2026	00:00	2,500		1	1			1		
	01:00	2,316		1	1			1		
	02:00	2,182		1	1			1		
	03:00	2,038		1	1			1		
	04:00	1,920		1	1			1		
	05:00	1,886		1	1			1		
	06:00	1,843		1	1			1		
	07:00	1,964		1	1			1		
	08:00	2,076		1	1			1		
	09:00	2,319		1	1			1		1
	10:00	2,497		1	1			1		1
	11:00	2,549		1	1			1		1
	12:00	2,585		1	1			1		1
	13:00	2,576		1	1			1		1
	14:00	2,585		1	1			1		1
	15:00	2,561		1	1			1		1
	16:00	2,569		1	1			1		1
	17:00	2,693		1	1			1		1
	18:00	2,882		1	1			1		1
	19:00	3,012		1	1			1		1
	20:00	3,089		1	1			1		1
	21:00	3,124		1	1			1		1
	22:00	2,810		1	1			1		1
	23:00	2,666		1	1			1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση