

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 29 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Τετάρτη, 29 Ιουλίου 2026	00:00	2,403			1		1		1	1
	01:00	2,257			1		1		1	1
	02:00	2,146			1		1		1	
	03:00	2,008			1		1		1	
	04:00	1,895			1		1		1	
	05:00	1,855			1		1		1	
	06:00	1,788			1		1		1	
	07:00	1,927			1		1		1	
	08:00	2,010			1		1		1	
	09:00	1,305			1		1		1	1
	10:00	1,515		1		1			1	
	11:00	1,951		1	1	1			1	
	12:00	2,371		1	1	1	1			
	13:00	2,307		1	1	1	1			
	14:00	2,272		1	1	1	1			
	15:00	2,312		1	1	1	1			
	16:00	2,310		1	1	1	1			1
	17:00	2,579		1		1	1			1
	18:00	2,679		1		1	1			1
	19:00	2,732		1		1	1			1
	20:00	2,764		1		1	1			1
	21:00	2,697		1		1	1			1
	22:00	2,540		1		1	1			1
	23:00	2,371		1		1	1			1

Μερική διακοπή στις 8:54 λόγω βλάβης στο δίκτυο. Γενικές διακοπές κατά το διάστημα 10:23 με 11:54 λόγω βλάβης στο δίκτυο.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 30 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Πέμπτη, 30 Ιουλίου 2026	00:00	2,148		1		1	1			1
	01:00	1,945		1		1	1			
	02:00	1,800		1		1	1			
	03:00	1,718		1		1	1			
	04:00	1,619		1		1	1			
	05:00	1,594		1		1	1			
	06:00	1,587		1		1	1			
	07:00	1,716		1		1	1			
	08:00	1,823		1		1	1			
	09:00	1,977		1		1	1			
	10:00	2,063		1			1			1
	11:00	2,145		1			1			1
	12:00	2,121		1			1			1
	13:00	2,187		1			1			1
	14:00	2,170		1			1			1
	15:00	2,123		1			1			1
	16:00	2,120		1			1			1
	17:00	2,199		1			1			1
	18:00	2,383		1		1	1			1
	19:00	2,480		1		1	1			1
	20:00	2,514		1		1	1			1
	21:00	2,496		1		1	1			1
	22:00	2,363		1		1	1			1
	23:00	2,124		1		1	1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 31 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)		0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000	
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Παρασκευή, 31 Ιουλίου 2026	00:00	1,879		1		1	1			
	01:00	1,725		1		1	1			
	02:00	1,596		1		1	1			
	03:00	1,528		1		1	1			
	04:00	1,450		1		1	1			
	05:00	1,407		1		1	1			
	06:00	1,442		1			1			
	07:00	1,560		1			1			
	08:00	1,723		1			1			1
	09:00	1,823		1			1			1
	10:00	1,987		1			1			1
	11:00	2,056		1			1			1
	12:00	2,081		1			1			1
	13:00	2,166		1			1			1
	14:00	2,145		1			1			1
	15:00	2,134		1			1			1
	16:00	2,106		1			1			1
	17:00	2,201		1			1			1
	18:00	2,347		1			1			1
	19:00	2,528		1	1		1			1
	20:00	2,536		1	1		1			1
	21:00	2,533		1	1		1			1
	22:00	2,386		1	1		1			1
	23:00	2,149		1	1		1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 1 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Σάββατο, 1 Αυγούστου 2026	00:00	1,901		1	1		1			
	01:00	1,737		1	1		1			
	02:00	1,603		1	1		1			
	03:00	1,535		1	1		1			
	04:00	1,463		1	1		1			
	05:00	1,447		1	1		1			
	06:00	1,427		1	1		1			
	07:00	1,564		1	1		1			
	08:00	1,729		1			1			1
	09:00	1,881		1			1			1
	10:00	2,011		1			1			1
	11:00	2,085		1			1			1
	12:00	2,149		1			1			1
	13:00	2,179		1			1			1
	14:00	2,134		1			1			1
	15:00	2,086		1			1			1
	16:00	2,073		1			1			1
	17:00	2,178		1			1			1
	18:00	2,334		1		1	1			1
	19:00	2,490		1		1	1			1
	20:00	2,597		1		1	1			1
	21:00	2,593		1		1	1			1
	22:00	2,368		1		1	1			1
	23:00	2,143		1		1	1			1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 2 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Κυριακή, 2 Αυγούστου 2026	00:00	1,895		1		1	1			
	01:00	1,731		1		1	1			
	02:00	1,620		1		1	1			
	03:00	1,562		1		1	1			
	04:00	1,475		1		1	1			
	05:00	1,472		1		1	1			
	06:00	1,462		1		1	1			
	07:00	1,614		1		1	1			
	08:00	1,740		1			1			1
	09:00	1,963		1			1			1
	10:00	2,081		1			1			1
	11:00	2,190		1			1			1
	12:00	2,203		1			1			1
	13:00	2,212		1			1			1
	14:00	2,193		1			1			1
	15:00	2,133		1			1			1
	16:00	2,097		1			1			1
	17:00	2,221		1			1			1
	18:00	2,408		1		1	1			1
	19:00	2,533		1		1	1			1
	20:00	2,553		1		1	1			1
	21:00	2,601		1		1	1			1
	22:00	2,373		1		1	1			1
	23:00	2,163		1		1	1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 3 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Δευτέρα, 3 Αυγούστου 2026	00:00	1,958		1		1	1			
	01:00	1,769		1		1	1			
	02:00	1,665		1		1	1			
	03:00	1,589		1		1	1			
	04:00	1,491		1		1	1			
	05:00	1,500		1		1	1			
	06:00	1,487		1		1				
	07:00	1,707		1		1				
	08:00	1,832		1		1				1
	09:00	2,048		1		1				1
	10:00	2,179		1		1				1
	11:00	2,257		1		1				1
	12:00	2,276		1		1				1
	13:00	2,269		1		1				1
	14:00	2,232		1		1				1
	15:00	2,285		1		1	1			1
	16:00	2,252		1		1	1			1
	17:00	2,343		1		1	1			1
	18:00	2,533		1		1	1			1
	19:00	2,700		1		1	1			1
	20:00	2,784		1		1	1			1
	21:00	2,740		1		1	1			1
	22:00	2,546		1		1	1			1
	23:00	2,355		1		1	1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 4 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Τρίτη, 4 Αυγούστου 2026	00:00	2,151		1		1	1			
	01:00	2,030		1		1	1			
	02:00	1,917		1		1	1			
	03:00	1,795		1		1	1			
	04:00	1,693		1		1	1			
	05:00	1,656		1		1	1			
	06:00	1,665			1		1	1		
	07:00	1,775			1		1	1		
	08:00	1,932			1		1	1		
	09:00	2,099					1	1		1
	10:00	2,237					1	1		1
	11:00	2,266					1	1		1
	12:00	2,344					1	1		1
	13:00	2,310					1	1		1
	14:00	2,346					1	1		1
	15:00	2,316					1	1		1
	16:00	2,295					1	1		1
	17:00	2,386					1	1		1
	18:00	2,556		1			1	1		1
	19:00	2,758		1			1	1		1
	20:00	2,899		1			1	1		1
	21:00	2,846		1			1	1		1
	22:00	2,636		1			1	1		1
	23:00	2,452		1			1	1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση