

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 13 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Πέμπτη, 13 Αυγούστου 2026	00:00	3,285			1		1	1	1	
	01:00	3,039			1		1	1	1	
	02:00	2,791			1		1	1	1	
	03:00	2,613			1		1	1	1	
	04:00	2,486			1		1		1	
	05:00	2,446			1		1		1	
	06:00	2,383			1		1		1	
	07:00	2,580			1		1		1	
	08:00	2,909		1	1		1		1	
	09:00	3,110		1	1		1		1	
	10:00	3,293		1	1		1		1	
	11:00	3,324		1	1		1	1		1
	12:00	3,448		1			1	1		1
	13:00	3,674		1			1	1		1
	14:00	3,569		1			1	1		1
	15:00	3,318		1			1	1		1
	16:00	3,349		1			1	1		1
	17:00	3,412		1			1	1		1
	18:00	3,630		1	1		1	1		1
	19:00	3,863			1		1	1	1	1
	20:00	3,950			1		1	1	1	1
	21:00	3,881			1		1	1	1	1
	22:00	3,481			1		1	1	1	1
	23:00	3,219			1		1	1	1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 14 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Παρασκευή, 14 Αυγούστου 2026	00:00	2,915			1		1	1	1	
	01:00	2,621			1		1	1	1	
	02:00	2,417			1			1	1	
	03:00	2,270			1			1	1	
	04:00	2,185			1			1	1	
	05:00	2,190			1			1	1	
	06:00	2,182			1			1	1	
	07:00	2,337			1			1	1	
	08:00	2,592			1	1		1		
	09:00	2,808			1	1		1		1
	10:00	2,909			1	1		1		1
	11:00	2,905			1	1		1		1
	12:00	3,024			1	1		1		1
	13:00	3,166			1	1		1		1
	14:00	3,058			1	1		1		1
	15:00	2,929			1	1		1		1
	16:00	2,892			1	1		1		1
	17:00	3,051			1	1		1		1
	18:00	3,294			1	1		1		1
	19:00	3,528			1	1		1		1
	20:00	3,746	1		1	1		1		1
	21:00	3,628	1		1	1		1		1
	22:00	3,293	1		1	1		1		1
	23:00	3,023	1		1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 15 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Σάββατο, 15 Αυγούστου 2026	00:00	2,735	1		1	1		1		
	01:00	2,483	1		1	1		1		
	02:00	2,242	1		1	1		1		
	03:00	2,113	1		1	1				
	04:00	2,045	1		1	1				
	05:00	2,073	1		1	1				
	06:00	2,142	1		1	1				
	07:00	2,315	1		1	1				
	08:00	2,580	1		1	1				
	09:00	2,819			1	1		1		1
	10:00	2,874			1	1		1		1
	11:00	2,987			1	1		1		1
	12:00	3,103			1	1		1		1
	13:00	3,052			1	1		1		1
	14:00	2,844			1	1		1		1
	15:00	2,630			1	1		1		1
	16:00	2,583			1	1		1		1
	17:00	2,826			1	1		1		1
	18:00	3,121			1	1		1		1
	19:00	3,188			1	1		1		1
	20:00	3,426			1	1		1		1
	21:00	3,355			1	1		1		1
	22:00	3,078			1	1		1		1
	23:00	2,765			1	1		1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 16 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Κυριακή, 16 Αυγούστου 2026	00:00	2,523			1	1		1		1
	01:00	2,426			1	1		1		
	02:00	2,244			1	1		1		
	03:00	2,071			1	1		1		
	04:00	2,013			1	1		1		
	05:00	2,011			1	1		1		
	06:00	2,037			1	1		1		
	07:00	2,142			1	1		1		
	08:00	2,367			1	1		1		
	09:00	2,568			1	1		1		1
	10:00	2,721			1	1	1			1
	11:00	2,749			1	1	1			1
	12:00	2,843			1	1	1			1
	13:00	2,879			1	1	1			1
	14:00	2,826			1	1	1			1
	15:00	2,764			1	1	1			1
	16:00	2,639			1	1	1			1
	17:00	2,841			1	1	1			1
	18:00	3,078			1	1	1			1
	19:00	3,295			1	1	1			1
	20:00	3,509			1	1	1			1
	21:00	3,438			1	1	1			1
	22:00	3,057			1	1	1			1
	23:00	2,848			1	1	1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 17 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Δευτέρα, 17 Αυγούστου 2026	00:00	2,498			1	1	1			1
	01:00	2,292			1	1	1		1	
	02:00	2,132			1	1			1	
	03:00	2,063			1	1			1	
	04:00	2,007			1	1			1	
	05:00	2,026			1	1			1	
	06:00	2,076			1	1			1	
	07:00	2,206			1	1			1	
	08:00	2,531			1	1				1
	09:00	2,681			1	1		1		1
	10:00	2,760			1	1		1		1
	11:00	2,858			1	1		1		1
	12:00	2,916			1	1		1		1
	13:00	2,987			1	1		1		1
	14:00	2,935			1	1		1		1
	15:00	2,789			1	1		1		1
	16:00	2,732			1	1		1		1
	17:00	2,802			1	1		1		1
	18:00	3,081			1	1		1		1
	19:00	3,414			1	1		1		1
	20:00	3,668	1		1	1		1		1
	21:00	3,580	1		1	1		1		1
	22:00	3,165	1		1	1		1		1
	23:00	2,870	1		1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 18 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Τρίτη, 18 Αυγούστου 2026	00:00	2,492	1		1	1		1		
	01:00	2,239	1		1			1		
	02:00	2,075	1		1			1		
	03:00	1,953	1		1			1		
	04:00	1,885	1		1			1		
	05:00	1,901	1		1			1		
	06:00	1,952	1		1			1		
	07:00	2,124	1		1			1		
	08:00	2,514			1			1		1
	09:00	2,719			1			1		1
	10:00	2,804			1		1	1		1
	11:00	2,904			1		1	1		1
	12:00	3,047			1		1	1		1
	13:00	3,086			1		1	1		1
	14:00	2,991			1		1	1		1
	15:00	2,785			1		1	1		1
	16:00	2,760			1		1	1		1
	17:00	2,895			1		1	1		1
	18:00	3,357			1		1	1		1
	19:00	3,503			1		1	1		1
	20:00	3,767			1		1	1	1	1
	21:00	3,596			1		1	1	1	1
	22:00	3,270			1		1	1	1	1
	23:00	3,001			1		1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 19 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Τετάρτη, 19 Αυγούστου 2026	00:00	2,733			1		1	1	1	
	01:00	2,458			1		1	1	1	
	02:00	2,318			1		1		1	
	03:00	2,184			1		1		1	
	04:00	2,098			1		1		1	
	05:00	2,081			1		1		1	
	06:00	2,140			1		1		1	
	07:00	2,314			1		1		1	
	08:00	2,711			1	1	1		1	
	09:00	3,047			1	1	1		1	
	10:00	3,295			1	1	1		1	
	11:00	3,244			1	1	1		1	
	12:00	3,410			1	1	1		1	
	13:00	3,359			1	1	1		1	
	14:00	3,362			1	1	1			1
	15:00	3,130			1	1	1			1
	16:00	3,046			1	1	1			1
	17:00	3,093			1	1	1			1
	18:00	3,411			1	1	1			1
	19:00	3,639			1	1	1	1		1
	20:00	3,901			1	1	1	1		1
	21:00	3,773			1	1	1	1		1
	22:00	3,310			1	1	1	1		1
	23:00	3,027			1	1	1	1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης