

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 20 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Πέμπτη, 20 Αυγούστου 2026	00:00	2,763			1	1	1	1		
	01:00	2,516			1	1	1	1		
	02:00	2,336			1	1		1		
	03:00	2,167			1	1		1		
	04:00	2,095			1	1		1		
	05:00	2,087			1	1		1		
	06:00	2,077			1	1		1		
	07:00	2,385			1	1		1		
	08:00	2,803		1	1	1		1		
	09:00	2,970		1	1	1		1		1
	10:00	3,158			1	1		1		1
	11:00	3,183			1	1		1		1
	12:00	3,291			1	1		1		1
	13:00	3,352			1	1		1		1
	14:00	3,315			1	1		1		1
	15:00	3,116			1	1		1		1
	16:00	3,067			1	1		1		1
	17:00	3,136			1	1		1		1
	18:00	3,473			1	1		1	1	1
	19:00	3,713			1	1		1	1	1
	20:00	3,953			1	1		1	1	1
	21:00	3,862			1	1		1	1	1
	22:00	3,502			1	1		1	1	1
	23:00	3,221			1	1		1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 21 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Παρασκευή, 21 Αυγούστου 2026	00:00	2,897			1	1		1	1	
	01:00	2,630			1	1		1	1	
	02:00	2,445			1			1	1	
	03:00	2,299			1			1	1	
	04:00	2,193			1			1	1	
	05:00	2,173			1			1	1	
	06:00	2,248			1			1	1	
	07:00	2,492			1			1	1	1
	08:00	2,806			1			1	1	1
	09:00	2,941			1			1	1	1
	10:00	3,020			1		1	1	1	1
	11:00	3,205			1	1	1	1		1
	12:00	3,244				1	1	1		1
	13:00	3,336				1	1	1		1
	14:00	3,327			1	1	1	1		1
	15:00	3,098			1		1	1		1
	16:00	3,067			1		1	1		1
	17:00	3,200			1		1	1		1
	18:00	3,407			1		1	1		1
	19:00	3,697	1	1	1		1	1		1
	20:00	3,763		1	1		1	1		1
	21:00	3,608		1	1		1	1		1
	22:00	3,320		1	1		1	1		1
	23:00	3,150		1			1	1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 22 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Σάββατο, 22 Αυγούστου 2026	00:00	2,883		1			1	1		1
	01:00	2,670		1			1	1		
	02:00	2,496		1			1	1		
	03:00	2,383		1			1	1		
	04:00	2,255		1			1	1		
	05:00	2,236		1			1	1		
	06:00	2,294		1			1	1		
	07:00	2,457		1			1	1		
	08:00	2,751		1			1	1		1
	09:00	2,984		1			1	1		1
	10:00	3,082		1			1	1		1
	11:00	3,149		1			1	1		1
	12:00	3,265		1			1	1		1
	13:00	3,237		1			1	1		1
	14:00	3,278		1			1	1		1
	15:00	3,209		1			1	1		1
	16:00	3,120		1			1	1		1
	17:00	3,184		1			1	1		1
	18:00	3,419		1			1	1		1
	19:00	3,678		1		1	1	1		1
	20:00	3,904		1		1	1	1		1
	21:00	3,676		1		1	1	1		1
	22:00	3,344		1		1	1	1		1
	23:00	3,127		1		1	1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 23 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Κυριακή, 23 Αυγούστου 2026	00:00	2,912		1		1	1	1		
	01:00	2,639		1		1	1			
	02:00	2,481		1		1	1			
	03:00	2,356		1		1	1			
	04:00	2,249		1		1	1			
	05:00	2,234		1		1	1			
	06:00	2,296		1		1	1			
	07:00	2,436		1		1	1			1
	08:00	2,700	1	1			1			1
	09:00	2,868	1	1			1			1
	10:00	3,031	1	1			1			1
	11:00	3,109	1	1			1			1
	12:00	3,417	1	1	1		1			1
	13:00	3,428		1	1		1			1
	14:00	3,475		1	1		1	1		1
	15:00	3,394			1		1	1		1
	16:00	3,338			1		1	1		1
	17:00	3,443			1		1	1		1
	18:00	3,603			1		1	1	1	1
	19:00	3,800			1		1	1	1	1
	20:00	4,052			1		1	1	1	1
	21:00	3,974			1		1	1	1	1
	22:00	3,650			1		1	1	1	1
	23:00	3,501			1		1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 24 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Δευτέρα, 24 Αυγούστου 2026	00:00	3,297			1		1	1	1	
	01:00	3,064			1		1	1	1	
	02:00	2,856			1		1	1	1	
	03:00	2,633			1		1	1		
	04:00	2,544			1		1	1		
	05:00	2,495			1		1	1		
	06:00	2,480			1		1	1		
	07:00	2,674			1		1	1		
	08:00	2,933			1		1	1		1
	09:00	3,089			1		1	1		1
	10:00	3,172			1		1	1		1
	11:00	3,244			1		1	1		1
	12:00	3,334			1		1	1		1
	13:00	3,407			1		1	1		1
	14:00	3,343			1		1	1		1
	15:00	3,191			1		1	1		1
	16:00	3,226			1		1	1		1
	17:00	3,285			1		1	1		1
	18:00	3,520			1		1	1	1	1
	19:00	3,646			1		1	1	1	1
	20:00	3,866			1		1	1	1	1
	21:00	3,890			1		1	1	1	1
	22:00	3,518			1		1	1	1	1
	23:00	3,291			1		1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 25 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Τρίτη, 25 Αυγούστου 2026	00:00	3,056			1		1	1	1	
	01:00	2,821			1		1	1	1	
	02:00	2,654			1		1	1	1	
	03:00	2,521			1			1	1	
	04:00	2,371			1			1	1	
	05:00	2,374			1			1	1	
	06:00	2,379			1			1	1	
	07:00	2,571			1			1	1	
	08:00	2,964			1	1		1	1	
	09:00	3,151			1	1		1	1	
	10:00	3,099			1	1		1	1	
	11:00	3,073			1	1		1		1
	12:00	3,215			1	1		1		1
	13:00	3,409			1	1		1		1
	14:00	3,285			1	1		1		1
	15:00	3,296			1	1		1		1
	16:00	3,237			1	1		1		1
	17:00	3,288			1	1		1		1
	18:00	3,505			1	1		1	1	1
	19:00	3,549			1	1		1	1	1
	20:00	3,777			1	1		1	1	1
	21:00	3,653			1	1		1	1	1
	22:00	3,316			1	1		1	1	1
	23:00	3,143			1	1		1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 26 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Τετάρτη, 26 Αυγούστου 2026	00:00	2,867			1	1		1	1	
	01:00	2,672			1	1		1	1	
	02:00	2,443			1			1	1	
	03:00	2,286			1			1	1	
	04:00	2,240			1			1	1	
	05:00	2,236			1			1	1	
	06:00	2,253			1			1	1	
	07:00	2,332			1			1	1	1
	08:00	2,458			1				1	1
	09:00	2,822			1		1		1	1
	10:00	2,981			1		1		1	1
	11:00	2,967		1	1		1			1
	12:00	3,125		1	1		1			1
	13:00	3,211		1	1		1			1
	14:00	3,174		1	1		1			1
	15:00	3,105		1	1		1			1
	16:00	3,056		1	1		1			1
	17:00	3,094		1	1		1			1
	18:00	3,395		1	1		1			1
	19:00	3,509		1	1		1		1	1
	20:00	3,682		1	1		1		1	1
	21:00	3,650		1	1		1		1	1
	22:00	3,376		1	1		1		1	1
	23:00	3,195		1	1		1		1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης