

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 30 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Πέμπτη, 30 Ιουλίου 2026	00:00	2,673	1			1	1			1
	01:00	2,382	1			1	1			
	02:00	2,149	1			1	1			
	03:00	2,077	1			1	1			
	04:00	2,041	1			1	1			
	05:00	2,025	1			1	1			
	06:00	2,031	1			1	1			
	07:00	2,248	1			1	1			
	08:00	2,502	1			1	1			1
	09:00	2,644	1			1	1			1
	10:00	2,712	1			1	1			1
	11:00	2,741	1			1	1			1
	12:00	2,887	1			1	1			1
	13:00	2,945	1			1	1			1
	14:00	2,827	1			1	1			1
	15:00	2,620	1			1	1			1
	16:00	2,562				1	1			1
	17:00	2,591				1	1			1
	18:00	2,879				1	1		1	1
	19:00	3,125				1	1		1	1
	20:00	3,228				1	1		1	1
	21:00	3,211				1	1		1	1
	22:00	2,893				1	1		1	1
	23:00	2,610				1	1		1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 31 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Παρασκευή, 31 Ιουλίου 2026	00:00	2,399				1	1		1	
	01:00	2,133				1	1		1	
	02:00	1,987				1	1		1	
	03:00	1,922				1	1		1	
	04:00	1,855				1	1		1	
	05:00	1,864				1	1		1	
	06:00	1,928				1	1		1	
	07:00	2,215				1	1			1
	08:00	2,462				1	1			1
	09:00	2,576				1	1			1
	10:00	2,656				1	1			1
	11:00	2,685		1		1	1			1
	12:00	2,798		1		1	1			1
	13:00	2,828		1		1	1			1
	14:00	2,711		1		1	1			1
	15:00	2,611		1			1			1
	16:00	2,551		1			1			1
	17:00	2,617		1			1			1
	18:00	2,904	1	1			1			1
	19:00	3,166	1	1			1			1
	20:00	3,238	1	1			1			1
	21:00	3,189	1	1			1			1
	22:00	2,883	1	1			1			1
	23:00	2,642	1	1			1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 1 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Σάββατο, 1 Αυγούστου 2026	00:00	2,491	1	1			1			
	01:00	2,215	1	1			1			
	02:00	2,049	1	1			1			
	03:00	1,994	1	1			1			
	04:00	1,940	1	1			1			
	05:00	1,895	1	1			1			
	06:00	1,913	1	1			1			
	07:00	2,130	1	1			1			
	08:00	2,306		1			1			1
	09:00	2,449		1			1			1
	10:00	2,521		1			1			1
	11:00	2,635		1			1			1
	12:00	2,755		1			1	1		1
	13:00	2,776		1			1	1		1
	14:00	2,717		1			1	1		1
	15:00	2,589		1				1		1
	16:00	2,610		1				1		1
	17:00	2,629		1				1		1
	18:00	2,837		1				1	1	1
	19:00	3,114		1				1	1	1
	20:00	3,323		1				1	1	1
	21:00	3,332		1				1	1	1
	22:00	2,952		1				1	1	1
	23:00	2,676		1				1	1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 2 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Κυριακή, 2 Αυγούστου 2026	00:00	2,497		1				1	1	
	01:00	2,243		1				1	1	
	02:00	2,064		1				1	1	
	03:00	2,004		1				1	1	
	04:00	1,934		1				1	1	
	05:00	1,944		1				1	1	
	06:00	1,930		1				1	1	
	07:00	2,123		1				1	1	
	08:00	2,304		1				1		1
	09:00	2,497		1				1		1
	10:00	2,627		1				1		1
	11:00	2,638		1				1		1
	12:00	2,783		1				1		1
	13:00	2,947		1				1	1	1
	14:00	2,808		1				1	1	1
	15:00	2,614		1				1	1	1
	16:00	2,520		1				1		1
	17:00	2,642		1				1		1
	18:00	2,889		1			1	1		1
	19:00	3,199		1			1	1		1
	20:00	3,340		1			1	1		1
	21:00	3,323		1			1	1		1
	22:00	3,102		1			1	1		1
	23:00	2,866		1			1	1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 3 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Δευτέρα, 3 Αυγούστου 2026	00:00	2,699		1			1	1		
	01:00	2,459		1			1	1		
	02:00	2,273		1			1	1		
	03:00	2,159		1			1	1		
	04:00	2,076		1			1	1		
	05:00	2,059		1			1	1		
	06:00	2,079		1			1	1		
	07:00	2,330	1				1	1		
	08:00	2,560	1				1	1		
	09:00	2,848	1				1	1		1
	10:00	3,022	1				1	1		1
	11:00	3,018	1				1	1		1
	12:00	2,970	1				1	1		1
	13:00	3,025	1				1	1		1
	14:00	3,023	1				1	1		1
	15:00	2,867	1				1	1		1
	16:00	2,769	1				1	1		1
	17:00	2,833	1				1	1		1
	18:00	3,124	1				1	1		1
	19:00	3,401	1				1	1		1
	20:00	3,456	1				1	1		1
	21:00	3,633	1				1	1		1
	22:00	3,243	1				1	1		1
	23:00	2,982	1				1	1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 4 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Τρίτη, 4 Αυγούστου 2026	00:00	2,749	1				1	1		1
	01:00	2,470	1				1	1		
	02:00	2,301	1				1	1		
	03:00	2,221	1				1	1		
	04:00	2,122	1				1	1		
	05:00	2,144	1				1	1		
	06:00	2,150	1				1	1		
	07:00	2,410	1				1	1		
	08:00	2,693					1	1		1
	09:00	2,952					1	1		1
	10:00	3,044					1	1	1	1
	11:00	3,099					1	1	1	1
	12:00	3,167					1	1	1	1
	13:00	3,382					1	1	1	1
	14:00	3,145					1	1	1	1
	15:00	3,037					1	1	1	1
	16:00	2,895					1	1	1	1
	17:00	3,042					1	1	1	1
	18:00	3,324					1	1	1	1
	19:00	3,529					1	1	1	1
	20:00	3,692					1	1	1	1
	21:00	3,846		1			1	1	1	1
	22:00	3,468		1			1	1	1	1
	23:00	3,264		1			1		1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 5 Αυγούστου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Τετάρτη, 5 Αυγούστου 2026	00:00	2,976		1			1		1	1
	01:00	2,729		1			1		1	1
	02:00	2,584		1			1		1	
	03:00	2,453		1			1		1	
	04:00	2,338		1			1		1	
	05:00	2,291		1			1		1	
	06:00	2,301		1			1		1	
	07:00	2,503		1			1		1	
	08:00	2,789	1				1		1	1
	09:00	3,038	1				1		1	1
	10:00	3,050	1				1		1	1
	11:00	3,140	1				1		1	1
	12:00	3,221	1				1		1	1
	13:00	3,283	1				1		1	1
	14:00	3,312	1				1		1	1
	15:00	3,188		1			1	1		1
	16:00	3,076		1			1	1		1
	17:00	3,197		1			1	1		1
	18:00	3,431		1			1	1		1
	19:00	3,682		1			1	1	1	1
	20:00	3,794		1			1	1	1	1
	21:00	3,891		1			1	1	1	1
	22:00	3,655		1			1	1	1	1
	23:00	3,471		1			1	1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης