

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Παρασκευή, 21 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Σ Κ Υ Ρ Ο Υ	Χρονική στιγμή	Πρόβλεψη Μέσου Ηλιαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Παρασκευή, 21 Αυγούστου 2026	00:00	2,683	1	1	1		1			
	01:00	2,466		1	1		1			
	02:00	2,315		1	1		1			
	03:00	2,189		1	1		1			
	04:00	2,099		1	1		1			
	05:00	2,039		1	1		1			
	06:00	2,087		1	1		1			
	07:00	2,290		1	1		1			
	08:00	2,560		1	1		1			1
	09:00	2,706		1	1		1			1
	10:00	2,820		1	1		1			1
	11:00	2,917		1	1		1			1
	12:00	3,001		1	1		1			1
	13:00	3,045		1	1		1			1
	14:00	3,055		1	1		1			1
	15:00	2,945		1	1		1			1
	16:00	2,881		1	1		1			1
	17:00	2,963		1	1		1			1
	18:00	3,247		1	1		1			1
	19:00	3,440		1	1		1	1		1
	20:00	3,552		1	1		1	1		1
	21:00	3,503		1	1		1	1		1
	22:00	3,249		1	1		1	1		
	23:00	2,956		1	1		1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Σάββατο, 22 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ηλιαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Σάββατο, 22 Αυγούστου 2026	00:00	2,662		1	1		1	1		
	01:00	2,472		1	1		1			
	02:00	2,340		1	1		1			
	03:00	2,227		1	1		1			
	04:00	2,132		1	1		1			
	05:00	2,065		1	1		1			
	06:00	2,067		1	1		1			
	07:00	2,211		1	1		1			
	08:00	2,477		1	1		1			
	09:00	2,634		1	1		1			1
	10:00	2,727		1	1		1			1
	11:00	2,796		1	1		1			1
	12:00	2,864		1	1		1			1
	13:00	2,902		1	1		1			1
	14:00	2,898		1	1		1			1
	15:00	2,832		1	1		1			1
	16:00	2,805		1	1		1			1
	17:00	2,901		1	1		1			1
	18:00	3,174		1	1		1			1
	19:00	3,407		1	1		1	1		1
	20:00	3,490		1	1		1	1		1
	21:00	3,445		1	1		1	1		1
	22:00	3,207		1	1		1	1		
	23:00	2,927		1	1		1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Κυριακή, 23 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Κυριακή, 23 Αυγούστου 2026	00:00	2,595		1	1		1	1		
	01:00	2,394		1	1		1			
	02:00	2,237		1	1		1			
	03:00	2,121		1	1		1			
	04:00	2,036		1	1		1			
	05:00	1,982		1	1		1			
	06:00	1,989		1	1		1			
	07:00	2,115		1	1		1			
	08:00	2,348		1	1		1			
	09:00	2,536		1	1		1			1
	10:00	2,684		1	1		1			1
	11:00	2,739		1	1		1			1
	12:00	2,789		1	1		1			1
	13:00	2,815		1	1		1			1
	14:00	2,810		1	1		1			1
	15:00	2,757		1	1		1			1
	16:00	2,703		1	1		1			1
	17:00	2,802		1	1		1			1
	18:00	3,063		1	1		1			1
	19:00	3,322		1	1		1			1
	20:00	3,402		1	1		1			1
	21:00	3,338		1	1		1			1
	22:00	3,101		1	1		1			1
	23:00	2,854		1	1		1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Δευτέρα, 24 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ηλιαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Δευτέρα, 24 Αυγούστου 2026	00:00	2,583		1	1		1			1
	01:00	2,467		1	1		1			
	02:00	2,326		1	1		1			
	03:00	2,206		1	1		1			
	04:00	2,117		1	1		1			
	05:00	2,071		1	1		1			
	06:00	2,089		1	1		1			
	07:00	2,195		1	1		1			
	08:00	2,398		1	1		1			
	09:00	2,568		1	1		1			1
	10:00	2,691		1	1		1			1
	11:00	2,776		1	1		1			1
	12:00	2,837		1	1		1			1
	13:00	2,874		1	1		1			1
	14:00	2,845		1	1		1			1
	15:00	2,744		1	1		1			1
	16:00	2,665		1	1		1			1
	17:00	2,750		1	1		1			1
	18:00	3,023		1	1		1			1
	19:00	3,334		1	1		1			1
	20:00	3,473		1	1		1	1		1
	21:00	3,382		1	1		1	1		1
	22:00	3,141		1	1		1	1		
	23:00	2,897		1	1		1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Τρίτη, 25 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ηλιαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Τρίτη, 25 Αυγούστου 2026	00:00	2,659		1	1		1	1		
	01:00	2,513		1	1		1			
	02:00	2,360		1	1		1			
	03:00	2,231		1	1		1			
	04:00	2,139		1	1		1			
	05:00	2,096		1	1		1			
	06:00	2,117		1	1		1			
	07:00	2,215		1	1		1			
	08:00	2,401		1	1		1			
	09:00	2,556		1	1		1			1
	10:00	2,661		1	1		1			1
	11:00	2,753		1	1		1			1
	12:00	2,833		1	1		1			1
	13:00	2,862		1	1		1			1
	14:00	2,803		1	1		1			1
	15:00	2,659		1	1		1			1
	16:00	2,570		1	1		1			1
	17:00	2,647		1	1		1			1
	18:00	2,956		1	1		1			1
	19:00	3,260		1	1		1			1
	20:00	3,420		1	1		1	1		1
	21:00	3,348		1	1		1	1		
	22:00	3,109		1	1		1	1		
	23:00	2,834		1	1		1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Τετάρτη, 26 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ηλιαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Τετάρτη, 26 Αυγούστου 2026	00:00	2,604		1	1		1	1		
	01:00	2,458		1	1		1			
	02:00	2,310		1	1		1			
	03:00	2,192		1	1		1			
	04:00	2,112		1	1		1			
	05:00	2,073		1	1		1			
	06:00	2,097		1	1		1			
	07:00	2,197		1	1		1			
	08:00	2,364		1	1		1			
	09:00	2,504		1	1		1			
	10:00	2,609		1	1		1			1
	11:00	2,680		1	1		1			1
	12:00	2,767		1	1		1			1
	13:00	2,798		1	1		1			1
	14:00	2,769		1	1		1			1
	15:00	2,632		1	1		1			1
	16:00	2,543		1	1		1			1
	17:00	2,612		1	1		1			1
	18:00	2,897		1	1		1			1
	19:00	3,183		1	1		1			1
	20:00	3,334		1	1		1			1
	21:00	3,310		1	1		1			1
	22:00	3,099		1	1		1			1
	23:00	2,860		1	1		1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Πέμπτη, 27 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Σ Κ Υ Ρ Ο Υ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Πέμπτη, 27 Αυγούστου 2026	00:00	2,602		1	1		1			1
	01:00	2,419		1	1		1			
	02:00	2,256		1	1		1			
	03:00	2,125		1	1		1			
	04:00	2,027		1	1		1			
	05:00	1,980		1	1		1			
	06:00	1,991		1	1		1			
	07:00	2,088		1	1		1			
	08:00	2,246		1	1		1			
	09:00	2,380		1	1		1			
	10:00	2,479		1	1		1			
	11:00	2,552		1	1		1			1
	12:00	2,621		1	1		1			1
	13:00	2,647		1	1		1			1
	14:00	2,612		1	1		1			1
	15:00	2,470		1	1		1			1
	16:00	2,385		1	1		1			1
	17:00	2,462		1	1		1			1
	18:00	2,728		1	1		1			1
	19:00	3,000		1	1		1			1
	20:00	3,122		1	1		1			1
	21:00	3,153		1	1		1			1
	22:00	2,998		1	1		1			1
	23:00	2,775		1	1		1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης