

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 28 Ιουλίου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 28 Ιουλίου 2026	00:00	2,241	1			1					1
	01:00	2,034	1			1					1
	02:00	1,918	1			1					1
	03:00	1,868	1			1					1
	04:00	1,796	1			1					1
	05:00	1,769	1			1					1
	06:00	1,743	1			1					1
	07:00	1,921	1			1					1
	08:00	2,237	1			1			1		
	09:00	2,600	1			1	1		1		
	10:00	2,808	1			1	1				1
	11:00	3,082	1			1	1				1
	12:00	3,206	1			1	1				1
	13:00	3,228	1			1	1				1
	14:00	3,269	1			1	1				1
	15:00	3,225	1			1	1		1		1
	16:00	3,043	1			1	1		1		1
	17:00	2,977	1			1	1				1
	18:00	3,159	1			1	1				1
	19:00	3,248	1			1	1				1
	20:00	3,245	1			1	1				1
	21:00	3,183	1			1	1				1
	22:00	3,128	1			1	1				1
	23:00	3,049	1			1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 29 Ιουλίου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Σ Υ Μ Η Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 29 Ιουλίου 2026	00:00	2,884	1			1	1				1
	01:00	2,731	1			1	1				1
	02:00	2,631	1			1	1				1
	03:00	2,531	1			1	1				1
	04:00	2,417	1			1	1				1
	05:00	2,358	1			1	1				1
	06:00	2,260	1			1	1				1
	07:00	2,392	1			1					1
	08:00	2,674	1			1	1				1
	09:00	2,919	1			1	1				1
	10:00	3,008	1			1	1				1
	11:00	3,190	1			1	1				1
	12:00	3,174	1			1	1				1
	13:00	3,241	1			1	1				1
	14:00	3,413	1			1	1			1	1
	15:00	3,321	1			1	1			1	1
	16:00	3,334	1			1	1			1	1
	17:00	3,391	1			1	1			1	1
	18:00	3,522	1			1	1			1	1
	19:00	3,487	1			1	1			1	1
	20:00	3,500	1			1	1			1	1
	21:00	3,472	1			1	1			1	1
	22:00	3,464	1			1	1			1	1
	23:00	3,310	1			1	1			1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 30 Ιουλίου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Σ Υ Μ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 30 Ιουλίου 2026	00:00	3,122	1				1			1	1
	01:00	2,889	1				1			1	1
	02:00	2,741	1				1			1	1
	03:00	2,647	1				1			1	1
	04:00	2,519	1				1			1	1
	05:00	2,446	1				1			1	1
	06:00	2,341	1				1			1	1
	07:00	2,463	1				1			1	1
	08:00	2,645	1				1			1	1
	09:00	2,737	1				1	1			1
	10:00	2,980	1				1	1			1
	11:00	3,250	1				1	1			1
	12:00	3,344	1				1	1			1
	13:00	3,459	1				1	1		1	1
	14:00	3,518	1				1	1		1	1
	15:00	3,400	1				1	1		1	1
	16:00	3,400	1				1	1		1	1
	17:00	3,468	1				1	1		1	1
	18:00	3,597	1				1	1		1	1
	19:00	3,477	1				1	1		1	1
	20:00	3,490	1				1	1		1	1
	21:00	3,463	1				1	1		1	1
	22:00	3,374	1				1	1		1	1
	23:00	2,876	1				1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 31 Ιουλίου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 31 Ιουλίου 2026	00:00	2,632	1			1	1				1
	01:00	2,379	1			1	1				1
	02:00	2,197	1			1					1
	03:00	2,132	1			1					1
	04:00	2,020	1			1					1
	05:00	1,955	1			1					1
	06:00	1,888	1			1					1
	07:00	2,101	1			1					1
	08:00	2,429	1			1					1
	09:00	2,863	1			1	1				1
	10:00	2,938	1			1	1				1
	11:00	3,119	1			1	1				1
	12:00	3,196	1			1	1				1
	13:00	3,339	1			1	1				1
	14:00	3,344	1			1	1				1
	15:00	3,377	1			1	1				1
	16:00	3,289	1			1	1				1
	17:00	3,344	1			1	1				1
	18:00	3,471	1			1	1			1	1
	19:00	3,501	1			1	1			1	1
	20:00	3,429	1			1	1			1	1
	21:00	3,318	1			1	1				1
	22:00	3,267	1			1	1				1
	23:00	3,137	1			1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 1 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 1 Αυγούστου 2026	00:00	2,930	1			1	1				1
	01:00	2,742	1			1	1				1
	02:00	2,644	1			1	1				1
	03:00	2,550	1			1	1				1
	04:00	2,459	1			1	1				1
	05:00	2,382	1			1					1
	06:00	2,239	1			1					1
	07:00	2,419	1			1					1
	08:00	2,651	1			1	1				1
	09:00	2,821	1			1	1				1
	10:00	2,974	1			1	1				1
	11:00	3,168	1			1	1				1
	12:00	3,258	1			1	1				1
	13:00	3,302	1			1	1				1
	14:00	3,359	1			1	1			1	1
	15:00	3,211	1			1	1			1	1
	16:00	3,204	1			1	1				1
	17:00	3,255	1			1	1				1
	18:00	3,425	1			1	1				1
	19:00	3,462	1			1	1			1	1
	20:00	3,489	1			1	1			1	1
	21:00	3,296	1			1	1			1	1
	22:00	3,106	1			1	1				1
	23:00	2,968	1			1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 2 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 2 Αυγούστου 2026	00:00	2,879	1			1	1				1
	01:00	2,702	1			1	1				1
	02:00	2,587	1			1	1				1
	03:00	2,531	1			1					1
	04:00	2,447	1			1					1
	05:00	2,375	1			1					1
	06:00	2,280	1			1					1
	07:00	2,414	1			1					1
	08:00	2,571	1			1					1
	09:00	2,801	1			1	1				1
	10:00	2,905	1			1	1				1
	11:00	3,035	1			1	1				1
	12:00	3,172	1			1	1				1
	13:00	3,278	1			1	1				1
	14:00	3,269	1			1	1				1
	15:00	3,140	1			1	1				1
	16:00	3,062	1			1	1				1
	17:00	3,062	1			1	1				1
	18:00	3,220	1			1	1				1
	19:00	3,291	1			1	1				1
	20:00	3,306	1			1	1				1
	21:00	3,258	1			1	1				1
	22:00	3,053	1			1	1				1
	23:00	2,472	1					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 3 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 3 Αυγούστου 2026	00:00	2,303	1			1					1
	01:00	2,114	1			1					1
	02:00	1,972	1			1					1
	03:00	1,892	1			1					1
	04:00	1,819	1			1					1
	05:00	1,786	1			1					1
	06:00	1,777	1			1					1
	07:00	1,973	1			1					1
	08:00	2,248	1			1					1
	09:00	2,629	1			1	1				1
	10:00	3,046	1			1	1				1
	11:00	3,203	1			1	1				1
	12:00	3,206	1			1	1				1
	13:00	3,300	1			1	1				1
	14:00	3,509	1			1	1			1	1
	15:00	3,369	1			1	1			1	1
	16:00	3,301	1			1	1				1
	17:00	3,305	1			1	1				1
	18:00	3,468	1			1	1			1	1
	19:00	3,487	1			1	1			1	1
	20:00	3,420	1			1	1			1	1
	21:00	3,440	1			1	1			1	1
	22:00	3,246	1			1	1				1
	23:00	3,064	1			1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης