

ΗΣ ΣΥΜΗΣ		Προτεινόμενος ΗΕΠ					Τετάρτη, 26 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 26 Αυγούστου 2026	00:00	3,126	1			1		1	1		
	01:00	2,972	1			1		1			
	02:00	2,834	1			1		1	1		
	03:00	2,707	1			1		1	1		
	04:00	2,580	1			1		1	1		
	05:00	2,479	1			1		1	1		
	06:00	2,447	1			1		1	1		
	07:00	2,553	1			1		1	1		
	08:00	2,762	1			1		1	1		
	09:00	2,937	1			1		1	1		
	10:00	3,086	1			1		1	1		
	11:00	3,249	1			1		1	1		
	12:00	3,392	1			1		1	1		
	13:00	3,483	1			1		1	1		
	14:00	3,496	1			1		1	1		
	15:00	3,415	1			1		1	1		
	16:00	3,368	1			1		1	1		
	17:00	3,378	1			1		1	1		
	18:00	3,493	1			1		1	1		
	19:00	3,559	1			1		1	1		
	20:00	3,586	1			1		1	1		
	21:00	3,537	1			1		1	1		
	22:00	3,424	1			1		1	1		
	23:00	3,287	1			1		1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Προτεινόμενος ΗΕΠ					Πέμπτη, 27 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 27 Αυγούστου 2026	00:00	3,113	1			1		1	1		
	01:00	2,962	1			1		1			
	02:00	2,824	1			1		1	1		
	03:00	2,703	1			1		1	1		
	04:00	2,579	1			1		1	1		
	05:00	2,492	1			1		1	1		
	06:00	2,471	1			1		1	1		
	07:00	2,570	1			1		1	1		
	08:00	2,765	1			1		1	1		
	09:00	2,936	1			1		1	1		
	10:00	3,107	1			1		1	1		
	11:00	3,264	1			1		1	1		
	12:00	3,403	1			1		1	1		
	13:00	3,493	1			1		1	1		
	14:00	3,516	1			1		1	1		
	15:00	3,479	1			1		1	1		
	16:00	3,452	1			1		1	1		
	17:00	3,467	1			1		1	1		
	18:00	3,563	1			1		1	1		
	19:00	3,633	1			1		1	1		
	20:00	3,687	1			1		1	1		
	21:00	3,642	1			1		1	1		
	22:00	3,509	1			1		1	1		
	23:00	3,308	1			1		1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 28 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 28 Αυγούστου 2026	00:00	3,154	1			1		1	1		
	01:00	2,999	1			1		1			
	02:00	2,860	1			1		1	1		
	03:00	2,755	1			1		1	1		
	04:00	2,623	1			1		1	1		
	05:00	2,532	1			1		1	1		
	06:00	2,507	1			1		1	1		
	07:00	2,615	1			1		1	1		
	08:00	2,793	1			1		1	1		
	09:00	2,971	1			1		1	1		
	10:00	3,143	1			1		1	1		
	11:00	3,302	1			1		1	1		
	12:00	3,442	1			1		1	1		
	13:00	3,531	1			1		1	1		
	14:00	3,559	1			1		1	1		
	15:00	3,524	1			1		1	1		
	16:00	3,500	1			1		1	1		
	17:00	3,531	1			1		1	1		
	18:00	3,628	1			1		1	1		
	19:00	3,706	1			1		1	1		
	20:00	3,718	1			1		1	1		
	21:00	3,679	1			1		1	1		
	22:00	3,573	1			1		1	1		
	23:00	3,411	1			1		1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Προτεινόμενος ΗΕΠ					Σάββατο, 29 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 29 Αυγούστου 2026	00:00	3,294	1			1		1	1		
	01:00	3,153	1			1		1			
	02:00	3,034	1			1		1			
	03:00	2,949	1			1		1			
	04:00	2,850	1			1		1			
	05:00	2,753	1			1		1			
	06:00	2,709	1			1		1			
	07:00	2,757	1			1		1			
	08:00	2,877	1			1		1			
	09:00	3,013	1			1		1			
	10:00	3,151	1			1		1			
	11:00	3,291	1			1		1			
	12:00	3,429	1			1		1			
	13:00	3,528	1			1		1			
	14:00	3,576	1			1		1			
	15:00	3,561	1			1		1			
	16:00	3,549	1			1		1			
	17:00	3,593	1			1		1			
	18:00	3,672	1			1		1			
	19:00	3,722	1			1		1			
	20:00	3,715	1			1		1			
	21:00	3,672	1			1		1			
	22:00	3,559	1			1		1			
	23:00	3,416	1			1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Προτεινόμενος ΗΕΠ					Κυριακή, 30 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 30 Αυγούστου 2026	00:00	3,339	1			1		1	1		
	01:00	3,208	1			1		1			
	02:00	3,100	1			1		1	1		
	03:00	2,990	1			1		1	1		
	04:00	2,839	1			1		1	1		
	05:00	2,698	1			1		1	1		
	06:00	2,612	1			1		1	1		
	07:00	2,630	1			1		1	1		
	08:00	2,784	1			1		1	1		
	09:00	2,922	1			1		1	1		
	10:00	3,065	1			1		1	1		
	11:00	3,225	1			1		1	1		
	12:00	3,358	1			1		1	1		
	13:00	3,452	1			1		1	1		
	14:00	3,478	1			1		1	1		
	15:00	3,449	1			1		1	1		
	16:00	3,414	1			1		1	1		
	17:00	3,426	1			1		1	1		
	18:00	3,498	1			1		1	1		
	19:00	3,568	1			1		1	1		
	20:00	3,587	1			1		1	1		
	21:00	3,555	1			1		1	1		
	22:00	3,467	1			1		1	1		
	23:00	3,340	1			1		1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Προτεινόμενος ΗΕΠ					Δευτέρα, 31 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 31 Αυγούστου 2026	00:00	3,227	1			1		1	1		
	01:00	3,082	1			1		1			
	02:00	2,952	1			1		1			
	03:00	2,821	1			1		1			
	04:00	2,686	1			1		1			
	05:00	2,589	1			1		1			
	06:00	2,548	1			1		1			
	07:00	2,602	1			1		1			
	08:00	2,771	1			1		1			
	09:00	2,935	1			1		1			
	10:00	3,102	1			1		1			
	11:00	3,301	1			1		1			
	12:00	3,500	1			1		1			
	13:00	3,627	1			1		1			
	14:00	3,657	1			1		1			
	15:00	3,595	1			1		1			
	16:00	3,544	1			1		1			
	17:00	3,540	1			1		1			
	18:00	3,604	1			1		1			
	19:00	3,666	1			1		1			
	20:00	3,681	1			1		1			
	21:00	3,667	1			1		1			
	22:00	3,587	1			1		1			
	23:00	3,444	1			1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Προτεινόμενος ΗΕΠ					Τρίτη, 1 Σεπτεμβρίου 2026				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 1 Σεπτεμβρίου 2026	00:00	3,280	1			1		1	1		
	01:00	3,141	1			1		1			
	02:00	3,028	1			1		1	1		
	03:00	2,908	1			1		1	1		
	04:00	2,776	1			1		1	1		
	05:00	2,666	1			1		1	1		
	06:00	2,617	1			1		1	1		
	07:00	2,665	1			1		1	1		
	08:00	2,819	1			1		1	1		
	09:00	2,979	1			1		1	1		
	10:00	3,139	1			1		1	1		
	11:00	3,325	1			1		1	1		
	12:00	3,501	1			1		1	1		
	13:00	3,623	1			1		1	1		
	14:00	3,658	1			1		1	1		
	15:00	3,599	1			1		1	1		
	16:00	3,559	1			1		1	1		
	17:00	3,584	1			1		1	1		
	18:00	3,674	1			1		1	1		
	19:00	3,735	1			1		1	1		
	20:00	3,726	1			1		1	1		
	21:00	3,682	1			1		1	1		
	22:00	3,569	1			1		1	1		
	23:00	3,412	1			1		1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης