

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Τετάρτη, 9 Σεπτεμβρίου 2026					
Αποδιδόμενη Ισχύς (kW)		110	110	110	100	100	100	150	
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 9 Σεπτεμβρίου 2026	00:00	90			1				
	01:00	83			1				
	02:00	81			1				
	03:00	80			1				
	04:00	80			1				
	05:00	80			1				
	06:00	76			1				
	07:00	75			1				
	08:00	79			1				
	09:00	88			1				
	10:00	95	1		1				
	11:00	100	1		1				
	12:00	106	1		1				
	13:00	108	1		1				
	14:00	109	1		1				
	15:00	107	1		1				
	16:00	106	1		1				
	17:00	104	1		1				
	18:00	105	1		1				
	19:00	102	1		1				
	20:00	110	1		1				
	21:00	113	1		1				
	22:00	111	1		1				
	23:00	103	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Πέμπτη, 10 Σεπτεμβρίου 2026					
Αποδιδόμενη Ισχύς (kW)		110	110	110	100	100	100	150	
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 10 Σεπτεμβρίου 2026	00:00	93			1				
	01:00	89			1				
	02:00	89			1				
	03:00	89			1				
	04:00	90			1				
	05:00	90			1				
	06:00	88			1				
	07:00	87			1				
	08:00	89			1				
	09:00	94	1		1				
	10:00	102	1		1				
	11:00	107	1		1				
	12:00	108	1		1				
	13:00	106	1		1				
	14:00	104	1		1				
	15:00	100	1		1				
	16:00	97	1		1				
	17:00	93	1		1				
	18:00	94	1		1				
	19:00	94	1		1				
	20:00	104	1		1				
	21:00	107	1		1				
	22:00	105	1		1				
	23:00	98	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Παρασκευή, 11 Σεπτεμβρίου 2026					
Αποδιδόμενη Ισχύς (kW)		110	110	110	100	100	100	150	
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 11 Σεπτεμβρίου 2026	00:00	89			1				
	01:00	85			1				
	02:00	82			1				
	03:00	81			1				
	04:00	80			1				
	05:00	80			1				
	06:00	80			1				
	07:00	78			1				
	08:00	80			1				
	09:00	85			1				
	10:00	91			1				
	11:00	98	1		1				
	12:00	102	1		1				
	13:00	104	1		1				
	14:00	102	1		1				
	15:00	101	1		1				
	16:00	98	1		1				
	17:00	93	1		1				
	18:00	92	1		1				
	19:00	90	1		1				
	20:00	100	1		1				
	21:00	104	1		1				
	22:00	101	1		1				
	23:00	95	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Σάββατο, 12 Σεπτεμβρίου 2026					
Αποδιδόμενη Ισχύς (kW)			110	110	110	100	100	100	150
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 12 Σεπτεμβρίου 2026	00:00	96	1		1				
	01:00	89			1				
	02:00	83			1				
	03:00	81			1				
	04:00	80			1				
	05:00	81			1				
	06:00	83			1				
	07:00	87			1				
	08:00	91			1				
	09:00	96	1		1				
	10:00	100	1		1				
	11:00	103	1		1				
	12:00	104	1		1				
	13:00	103	1		1				
	14:00	101	1		1				
	15:00	99	1		1				
	16:00	99	1		1				
	17:00	97	1		1				
	18:00	94	1		1				
	19:00	97	1		1				
	20:00	106	1		1				
	21:00	110	1		1				
	22:00	108	1		1				
	23:00	102	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Κυριακή, 13 Σεπτεμβρίου 2026					
Αποδιδόμενη Ισχύς (kW)			110	110	110	100	100	100	150
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 13 Σεπτεμβρίου 2026	00:00	96	1		1				
	01:00	91			1				
	02:00	89			1				
	03:00	88			1				
	04:00	87			1				
	05:00	86			1				
	06:00	85			1				
	07:00	84			1				
	08:00	85			1				
	09:00	90			1				
	10:00	96	1		1				
	11:00	100	1		1				
	12:00	102	1		1				
	13:00	103	1		1				
	14:00	100	1		1				
	15:00	98	1		1				
	16:00	96	1		1				
	17:00	94	1		1				
	18:00	92	1		1				
	19:00	93	1		1				
	20:00	100	1		1				
	21:00	104	1		1				
	22:00	105	1		1				
	23:00	102	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Δευτέρα, 14 Σεπτεμβρίου 2026					
Αποδιδόμενη Ισχύς (kW)		110	110	110	100	100	100	150	
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 14 Σεπτεμβρίου 2026	00:00	91			1				
	01:00	84			1				
	02:00	81			1				
	03:00	80			1				
	04:00	80			1				
	05:00	80			1				
	06:00	80			1				
	07:00	80			1				
	08:00	84			1				
	09:00	92			1				
	10:00	99	1		1				
	11:00	104	1		1				
	12:00	107	1		1				
	13:00	107	1		1				
	14:00	106	1		1				
	15:00	101	1		1				
	16:00	98	1		1				
	17:00	94	1		1				
	18:00	90	1		1				
	19:00	92	1		1				
	20:00	101	1		1				
	21:00	102	1		1				
	22:00	100	1		1				
	23:00	94	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Τρίτη, 15 Σεπτεμβρίου 2026					
Αποδιδόμενη Ισχύς (kW)			110	110	110	100	100	100	150
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 15 Σεπτεμβρίου 2026	00:00	87			1				
	01:00	82			1				
	02:00	80			1				
	03:00	80			1				
	04:00	81			1				
	05:00	81			1				
	06:00	82			1				
	07:00	83			1				
	08:00	87			1				
	09:00	93	1		1				
	10:00	101	1		1				
	11:00	106	1		1				
	12:00	108	1		1				
	13:00	107	1		1				
	14:00	106	1		1				
	15:00	103	1		1				
	16:00	99	1		1				
	17:00	96	1		1				
	18:00	96	1		1				
	19:00	97	1		1				
	20:00	104	1		1				
	21:00	106	1		1				
	22:00	104	1		1				
	23:00	99	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης