

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 1 Σεπτεμβρίου 2026								
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τρίτη, 1 Σεπτεμβρίου 2026	00:00	44,83	1	1	1	1	1	1	1		1	1	
	01:00	41,92	1	1	1	1	1	1	1		1	1	
	02:00	39,93	1	1	1	1	1	1	1		1	1	
	03:00	38,60	1	1	1	1	1	1	1		1	1	
	04:00	37,80	1	1	1	1	1	1	1		1	1	
	05:00	38,02	1	1	1	1	1	1	1		1	1	
	06:00	39,58	1	1	1	1	1	1	1		1	1	
	07:00	43,77	1		1	1	1	1	1		1	1	
	08:00	48,96	1		1	1	1	1	1		1	1	3
	09:00	52,44	1	1	1	1	1	1	1		1	1	1
	10:00	54,75	1	1	1	1	1	1	1		1	1	
	11:00	55,72	1	1	1	1	1	1	1		1	1	
	12:00	57,47	1	1	1	1	1	1	1		1	1	2
	13:00	58,81	1	1	1	1	1	1	1		1	1	3
	14:00	58,67	1	1	1	1	1	1	1		1	1	7
	15:00	58,15	1	1	1	1	1	1	1	1	1	1	4
	16:00	57,39	1	1	1	1	1	1	1	1	1	1	1
	17:00	57,27	1	1	1	1	1	1	1	1	1	1	
	18:00	57,61	1	1	1	1	1	1	1	1	1	1	
	19:00	56,33	1	1	1	1	1	1	1	1	1	1	
	20:00	57,09	1	1	1	1	1	1	1	1	1	1	
	21:00	56,00	1	1	1	1	1	1	1	1	1	1	
	22:00	53,59	1	1	1	1	1	1	1	1	1	1	
	23:00	48,33	1	1	1	1	1	1	1	1	1	1	

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης