

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας		Σάββατο, 12 Σεπτεμβρίου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Σάββατο, 12 Σεπτεμβρίου 2026	00:00	41,90	1	1	1	1		1	1		1	1	
	01:00	39,08	1	1	1	1		1	1		1	1	
	02:00	37,68	1	1	1	1		1	1		1	1	
	03:00	36,43	1	1	1	1		1	1		1	1	
	04:00	35,89	1	1	1	1		1	1		1	1	
	05:00	35,99	1	1	1	1		1	1		1	1	
	06:00	37,69	1	1	1	1		1	1		1	1	
	07:00	41,14	1	1	1	1		1	1		1	1	
	08:00	46,61	1	1	1	1		1	1		1	1	
	09:00	50,01	1	1	1	1	1	1	1		1	1	2
	10:00	52,16	1	1	1	1	1	1	1		1	1	2
	11:00	52,77	1	1	1	1	1	1	1		1	1	2
	12:00	54,37	1	1	1	1	1	1	1		1	1	4
	13:00	55,46	1	1	1	1	1	1	1		1	1	4
	14:00	55,58	1	1	1	1	1	1	1		1	1	4
	15:00	54,86	1	1	1	1	1	1	1		1	1	4
	16:00	54,09	1	1	1	1	1	1	1		1	1	4
	17:00	53,97	1	1	1	1	1	1	1		1	1	3
	18:00	54,14	1	1	1	1	1	1	1		1	1	3
	19:00	54,17	1	1	1	1	1	1	1		1	1	3
	20:00	55,01	1	1	1	1	1	1	1		1	1	3
	21:00	53,20	1	1	1	1	1	1	1		1	1	3
	22:00	50,76	1	1	1	1	1	1	1		1	1	1
	23:00	46,61	1	1	1	1	1	1	1		1	1	

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης