

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 13 Σεπτεμβρίου 2026								
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Κυριακή, 13 Σεπτεμβρίου 2026	00:00	42,30	1		1	1	1	1	1		1	1	
	01:00	39,84	1		1	1	1	1	1		1	1	
	02:00	38,14	1		1	1	1	1	1		1	1	
	03:00	36,82	1		1	1	1	1	1		1	1	
	04:00	36,44	1		1	1	1	1	1		1	1	
	05:00	36,02	1		1	1	1	1	1		1	1	
	06:00	37,46	1		1	1	1	1	1		1	1	
	07:00	41,77	1		1	1	1	1	1		1	1	
	08:00	45,69	1	1	1	1	1	1	1		1	1	
	09:00	48,88	1	1	1	1	1	1	1		1	1	
	10:00	51,04	1	1	1	1	1	1	1		1	1	1
	11:00	52,01	1	1	1	1	1	1	1	1	1	1	
	12:00	54,21	1	1	1	1	1	1	1	1	1	1	
	13:00	55,64	1	1	1	1	1	1	1	1	1	1	
	14:00	55,08	1	1	1	1	1	1	1	1	1	1	3
	15:00	53,06	1	1	1	1	1	1	1	1	1	1	1
	16:00	52,19	1	1	1	1	1	1	1	1	1	1	
	17:00	52,97	1	1	1	1	1	1	1	1	1	1	
	18:00	52,83	1	1	1	1	1	1	1	1	1	1	
	19:00	52,88	1	1	1	1	1	1	1	1	1	1	
	20:00	53,69	1	1	1	1	1	1	1	1	1	1	
	21:00	52,38	1	1	1	1	1	1	1	1	1	1	
	22:00	49,54	1	1	1	1	1	1	1	1	1	1	
	23:00	45,42	1	1	1	1	1	1	1		1	1	

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης