

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 15 Σεπτεμβρίου 2026								
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τρίτη, 15 Σεπτεμβρίου 2026	00:00	41,37	1	1	1		1	1	1		1	1	
	01:00	38,38	1	1	1		1	1	1		1	1	
	02:00	36,73	1	1	1		1	1	1		1	1	
	03:00	36,03	1	1	1		1	1	1		1	1	
	04:00	35,44	1	1	1		1	1	1		1	1	
	05:00	35,61	1	1	1		1	1	1		1	1	
	06:00	37,96	1	1	1		1	1	1		1	1	
	07:00	41,90	1	1	1		1	1	1		1	1	
	08:00	45,66	1	1	1	1	1	1	1		1	1	
	09:00	48,88	1	1	1	1	1	1	1		1	1	
	10:00	50,27	1	1	1	1	1	1	1		1	1	
	11:00	50,85	1	1	1	1	1	1	1		1	1	
	12:00	52,35	1	1	1	1	1	1	1		1	1	3
	13:00	53,60	1		1	1	1	1	1	1	1	1	2
	14:00	52,73	1		1	1	1	1	1	1	1	1	
	15:00	51,30	1		1	1	1	1	1	1	1	1	
	16:00	49,67	1		1	1	1	1	1	1	1	1	
	17:00	49,11	1		1	1	1	1	1	1	1	1	
	18:00	49,84	1		1	1	1	1	1	1	1	1	
	19:00	52,16	1		1	1	1	1	1	1	1	1	
	20:00	52,73	1		1	1	1	1	1	1	1	1	
	21:00	51,15	1		1	1	1	1	1	1	1	1	
	22:00	47,66	1		1	1	1	1	1	1	1	1	
	23:00	43,39	1		1	1	1	1	1		1	1	

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης