

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 17 Σεπτεμβρίου 2026								
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Πέμπτη, 17 Σεπτεμβρίου 2026	00:00	40,26	1		1	1	1	1	1		1	1	
	01:00	37,47	1		1	1	1	1	1		1	1	
	02:00	35,84	1		1	1	1	1	1		1	1	
	03:00	34,82	1		1	1	1	1	1		1	1	
	04:00	34,78	1		1	1	1	1	1		1	1	
	05:00	34,78	1		1	1	1	1	1		1	1	
	06:00	37,04	1		1	1	1	1	1		1	1	
	07:00	41,76	1		1	1	1	1	1		1	1	1
	08:00	46,08	1		1	1	1	1	1	1	1	1	2
	09:00	48,71	1		1	1	1	1	1	1	1	1	1
	10:00	49,55	1		1	1	1	1	1	1	1	1	1
	11:00	49,39	1		1	1	1	1	1	1	1	1	
	12:00	50,75	1		1	1	1	1	1	1	1	1	
	13:00	51,21	1		1	1	1	1	1	1	1	1	
	14:00	51,08	1		1	1	1	1	1	1	1	1	
	15:00	49,38	1		1	1	1	1	1	1	1	1	
	16:00	48,64	1		1	1	1	1	1	1	1	1	
	17:00	49,38	1		1	1	1	1	1	1	1	1	
	18:00	50,59	1		1	1	1	1	1	1	1	1	
	19:00	51,80	1		1	1	1	1	1	1	1	1	
	20:00	52,53	1		1	1	1	1	1	1	1	1	
	21:00	51,05	1		1	1	1	1	1	1	1	1	
	22:00	48,16	1		1	1	1	1	1	1	1	1	
	23:00	43,92	1		1	1	1	1	1	1	1	1	

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης