

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας		Σάββατο, 19 Σεπτεμβρίου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Σάββατο, 19 Σεπτεμβρίου 2026	00:00	40,19	1		1	1	1	1	1	1	1		
	01:00	38,12	1		1	1	1	1	1	1	1		
	02:00	36,50	1		1	1	1	1	1	1	1		
	03:00	35,41	1		1	1	1	1	1	1	1		
	04:00	34,71	1		1	1	1	1	1	1	1		
	05:00	35,25	1		1	1	1	1	1	1	1		
	06:00	37,31	1		1	1	1	1	1	1	1		
	07:00	41,02	1		1	1	1	1	1	1	1	1	
	08:00	45,57	1		1	1	1	1	1	1	1	1	
	09:00	48,01	1		1	1	1	1	1	1	1	1	
	10:00	49,43	1		1	1	1	1	1	1	1	1	2
	11:00	50,21	1		1	1	1	1	1	1	1	1	3
	12:00	51,67	1		1	1	1	1	1	1	1	1	3
	13:00	52,12	1		1	1	1	1	1	1	1	1	3
	14:00	51,68	1		1	1	1	1	1	1	1	1	1
	15:00	50,84	1		1	1	1	1	1	1	1	1	1
	16:00	50,22	1		1	1	1	1	1	1	1	1	1
	17:00	50,53	1		1	1	1	1	1	1	1	1	
	18:00	51,28	1		1	1	1	1	1	1	1	1	
	19:00	51,01	1		1	1	1	1	1	1	1	1	
	20:00	49,87	1		1	1	1	1	1	1	1	1	
	21:00	49,46	1		1	1	1	1	1	1	1	1	
	22:00	47,59	1		1	1	1	1	1	1	1	1	
	23:00	44,00	1		1	1	1	1	1	1	1	1	

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης