

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 20 Σεπτεμβρίου 2026								
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Κυριακή, 20 Σεπτεμβρίου 2026	00:00	40,20	1		1	1	1		1	1	1	1	
	01:00	37,72	1		1	1	1		1	1	1	1	
	02:00	36,39	1		1	1	1		1	1	1	1	
	03:00	35,49	1		1	1	1		1	1	1	1	
	04:00	35,24	1		1	1	1		1	1	1	1	
	05:00	35,60	1		1	1	1		1	1	1	1	
	06:00	37,08	1		1	1	1		1	1	1	1	
	07:00	40,13	1		1	1	1		1	1	1	1	
	08:00	44,48	1		1	1	1		1	1	1	1	
	09:00	46,85	1		1	1	1		1	1	1	1	
	10:00	48,25	1		1	1	1		1	1	1	1	
	11:00	48,43	1	1	1	1	1		1	1	1	1	
	12:00	49,28	1	1	1	1	1		1	1	1	1	
	13:00	50,01	1	1	1	1	1		1	1	1	1	
	14:00	49,48	1	1	1	1	1		1	1	1	1	3
	15:00	48,48	1		1	1	1		1	1	1	1	3
	16:00	47,84	1		1	1	1		1	1	1	1	2
	17:00	48,27	1	1	1	1	1		1	1	1	1	
	18:00	49,50	1	1	1	1	1		1	1	1	1	
	19:00	50,57	1	1	1	1	1		1	1	1	1	
	20:00	51,31	1	1	1	1	1		1	1	1	1	
	21:00	50,18	1	1	1	1	1		1	1	1	1	
	22:00	47,04	1	1	1	1	1		1	1	1	1	
	23:00	42,84	1	1	1	1	1		1	1	1	1	

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης