

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας		Δευτέρα, 21 Σεπτεμβρίου 2026										
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	
Δευτέρα, 21 Σεπτεμβρίου 2026	00:00	39,69	1		1	1	1		1	1	1	1		
	01:00	37,46	1		1	1	1		1	1	1	1		
	02:00	35,39	1		1	1	1		1	1	1	1	1	
	03:00	34,68	1		1	1	1		1	1	1	1	1	
	04:00	34,63	1		1	1	1		1	1	1	1	1	
	05:00	34,97	1		1	1	1		1	1	1	1	1	
	06:00	37,03	1		1	1	1		1	1	1	1	1	
	07:00	41,68	1		1	1	1		1	1	1	1	1	
	08:00	45,92	1	1	1	1	1		1	1	1	1	1	
	09:00	48,32	1	1	1	1	1		1	1	1	1	1	
	10:00	49,53	1	1	1	1	1		1	1	1	1	1	
	11:00	50,13	1	1	1	1	1		1	1	1	1	1	
	12:00	51,30	1	1	1	1	1		1	1	1	1	1	
	13:00	51,78	1	1	1	1	1		1	1	1	1	1	
	14:00	51,17	1	1	1	1	1		1	1	1	1	1	
	15:00	50,28	1	1	1	1	1		1	1	1	1	1	
	16:00	49,83	1	1	1	1	1		1	1	1	1	1	
	17:00	50,08	1	1	1	1	1		1	1	1	1	1	
	18:00	50,84	1	1	1	1	1		1	1	1	1	1	
	19:00	51,57	1	1	1	1	1		1	1	1	1	1	
	20:00	52,21	1	1	1	1	1		1	1	1	1	1	
	21:00	50,38	1	1	1	1	1		1	1	1	1	1	
	22:00	47,62	1	1	1	1	1		1	1	1	1	1	
	23:00	43,22	1	1	1	1	1		1	1		1	1	

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης