

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 22 Σεπτεμβρίου 2026								
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τρίτη, 22 Σεπτεμβρίου 2026	00:00	39,59	1	1	1	1	1		1		1	1	
	01:00	36,96	1	1	1	1	1		1		1	1	
	02:00	35,38	1	1	1	1	1		1		1	1	
	03:00	34,70	1	1	1	1	1		1		1	1	
	04:00	33,97	1	1	1	1	1		1		1	1	
	05:00	33,70	1	1	1	1	1		1		1	1	
	06:00	36,05	1	1	1	1	1		1		1	1	
	07:00	40,72	1	1	1	1	1		1		1	1	2
	08:00	45,90	1	1	1	1	1		1		1	1	2
	09:00	48,50	1	1	1	1	1		1		1	1	2
	10:00	49,32	1	1	1	1	1		1		1	1	3
	11:00	50,21	1	1	1	1	1		1		1	1	3
	12:00	50,98	1	1	1	1	1		1		1	1	4
	13:00	51,38	1	1	1	1	1		1		1	1	4
	14:00	51,40	1	1	1	1	1		1		1	1	4
	15:00	50,27	1	1	1	1	1		1		1	1	4
	16:00	49,17	1	1	1	1	1		1		1	1	4
	17:00	49,09	1	1	1	1	1		1		1	1	4
	18:00	49,90	1	1	1	1	1		1		1	1	4
	19:00	51,31	1	1	1	1	1		1		1	1	5
	20:00	52,32	1	1	1	1	1		1		1	1	5
	21:00	51,00	1	1	1	1	1		1		1	1	5
	22:00	47,09	1	1	1	1	1		1		1	1	2
	23:00	42,37	1	1	1	1	1		1		1	1	

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης