

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 31 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	νοικ. H/ (x20)
Δευτέρα, 31 Αυγούστου 2026	00:00	44,62	1	1	1	1	1	1	1		1	1		1
	01:00	42,21	1	1	1	1	1	1	1		1	1		
	02:00	40,35	1	1	1	1	1	1	1		1	1		
	03:00	39,21	1	1	1	1	1	1	1		1	1		
	04:00	38,39	1	1	1	1	1	1	1		1	1		
	05:00	38,34	1	1	1	1	1	1	1		1	1		
	06:00	39,60	1	1	1	1	1	1	1		1	1		
	07:00	44,09	1	1	1	1	1	1	1		1	1		
	08:00	48,75	1	1	1	1	1	1	1		1	1	1	1
	09:00	52,67	1	1	1	1	1	1	1		1	1		3
	10:00	54,72	1	1	1	1	1	1	1		1	1		8
	11:00	55,98	1	1	1	1	1	1	1		1	1		8
	12:00	57,79	1	1	1	1	1	1	1		1	1		11
	13:00	58,53	1	1	1	1	1	1	1		1	1		12
	14:00	58,52	1	1	1	1	1	1	1		1	1		12
	15:00	57,78	1	1	1	1	1	1	1		1	1		12
	16:00	57,54	1	1	1	1	1	1	1		1	1		12
	17:00	57,43	1	1	1	1	1	1	1		1	1		12
	18:00	57,55	1	1	1	1	1	1	1		1	1		11
	19:00	56,53	1	1	1	1	1	1	1		1	1		10
	20:00	56,91	1	1	1	1	1	1	1		1	1	1	8
	21:00	56,22	1	1	1	1	1	1	1		1	1	2	6
	22:00	53,35	1	1	1	1	1	1	1		1	1	2	6
	23:00	48,74	1	1	1	1	1	1	1		1	1		3

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης