

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα, 1 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Δευτέρα, 1 Ιουνίου 2026	00:00	35,75	1	1		1	1	1		1	1		
	01:00	33,17	1	1		1	1	1		1	1		
	02:00	31,70	1	1		1	1	1		1	1		
	03:00	30,77	1	1		1	1	1		1	1		
	04:00	30,20	1	1		1	1	1		1	1		
	05:00	30,41	1	1		1	1	1		1	1		
	06:00	32,24	1	1		1	1	1		1	1		
	07:00	35,60	1	1		1	1	1		1	1		
	08:00	38,90	1	1		1	1	1		1	1	1	
	09:00	40,77	1	1		1	1	1		1	1	1	
	10:00	41,85	1	1		1	1	1		1	1	1	
	11:00	43,05	1	1		1	1	1		1	1	1	
	12:00	43,97	1	1		1	1	1		1	1	1	
	13:00	44,51	1	1		1	1	1		1	1	1	
	14:00	44,30	1	1		1	1	1		1	1	1	
	15:00	43,53	1	1		1	1	1		1	1	1	
	16:00	42,85	1	1		1	1	1		1	1	1	
	17:00	42,79	1	1		1	1	1		1	1	1	
	18:00	43,20	1	1		1	1	1		1	1	1	
	19:00	44,08	1	1		1	1	1		1	1	1	
	20:00	44,98	1	1		1	1	1		1	1	1	
	21:00	45,29	1	1		1	1	1		1	1	1	
	22:00	43,48	1	1		1	1	1		1	1	1	
	23:00	39,70	1	1		1	1	1		1	1	1	

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη, 2 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τρίτη, 2 Ιουνίου 2026	00:00	35,99	1	1		1	1	1		1	1		
	01:00	33,18	1	1		1	1	1		1	1		
	02:00	31,57	1	1		1	1	1		1	1		
	03:00	30,65	1	1		1	1	1		1	1		
	04:00	30,20	1	1		1	1	1		1	1		
	05:00	30,61	1	1		1	1	1		1	1		
	06:00	32,66	1	1		1	1	1		1	1		
	07:00	35,97	1	1		1	1	1		1	1		
	08:00	39,11	1	1		1	1	1		1	1	1	
	09:00	41,06	1	1		1	1	1		1	1	1	
	10:00	42,02	1	1		1	1	1		1	1	1	
	11:00	43,10	1	1		1	1	1		1	1	1	
	12:00	44,12	1	1		1	1	1		1	1	1	
	13:00	44,85	1	1		1	1	1		1	1	1	
	14:00	44,83	1	1		1	1	1		1	1	1	
	15:00	43,93	1	1		1	1	1		1	1	1	
	16:00	42,93	1	1		1	1	1		1	1	1	
	17:00	42,75	1	1		1	1	1		1	1	1	
	18:00	43,26	1	1		1	1	1		1	1	1	
	19:00	44,14	1	1		1	1	1		1	1	1	
	20:00	44,97	1	1		1	1	1		1	1	1	
	21:00	45,08	1	1		1	1	1		1	1	1	
	22:00	43,37	1	1		1	1	1		1	1	1	
	23:00	39,89	1	1		1	1	1		1	1	1	

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη, 3 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τετάρτη, 3 Ιουνίου 2026	00:00	36,06	1	1			1	1		1	1		
	01:00	33,16	1	1			1	1		1	1		
	02:00	31,41	1	1			1	1		1	1		
	03:00	30,36	1	1			1	1		1	1		
	04:00	29,89	1	1			1	1		1	1		
	05:00	30,36	1	1			1	1		1	1		
	06:00	32,32	1	1			1	1		1	1		
	07:00	36,15	1	1			1	1		1	1		
	08:00	40,38	1	1			1	1		1	1	1	
	09:00	43,22	1	1			1	1		1	1	1	
	10:00	44,52	1	1			1	1		1	1	1	
	11:00	45,36	1	1			1	1		1	1	1	
	12:00	45,87	1	1			1	1		1	1	1	
	13:00	46,44	1	1			1	1		1	1	1	
	14:00	46,06	1	1			1	1		1	1	1	
	15:00	44,97	1	1			1	1		1	1	1	
	16:00	44,14	1	1			1	1		1	1	1	
	17:00	44,23	1	1			1	1		1	1	1	
	18:00	44,80	1	1			1	1		1	1	1	
	19:00	44,72	1	1			1	1		1	1	1	
	20:00	45,74	1	1			1	1		1	1	1	
	21:00	45,20	1	1			1	1		1	1	1	
	22:00	43,47	1	1			1	1		1	1	1	
	23:00	40,21	1	1			1	1		1	1	1	

Επτά φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη, 4 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η Ε Ρ Ε Σ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Πέμπτη, 4 Ιουνίου 2026	00:00	37,05	1	1			1	1		1	1		
	01:00	34,23	1	1			1	1		1	1		
	02:00	32,45	1	1			1	1		1	1		
	03:00	31,36	1	1			1	1		1			
	04:00	30,85	1	1			1	1		1			
	05:00	31,23	1	1			1	1		1			
	06:00	32,95	1	1			1	1		1	1		
	07:00	36,36	1	1			1	1		1	1		
	08:00	39,84	1	1			1	1		1	1		
	09:00	42,46	1	1			1	1		1	1		
	10:00	43,80	1	1			1	1		1	1	1	
	11:00	44,48	1	1			1	1		1	1	1	
	12:00	45,14	1	1			1	1		1	1	1	
	13:00	45,50	1	1			1	1		1	1	1	
	14:00	45,29	1	1			1	1		1	1	1	
	15:00	44,47	1	1			1	1		1	1	1	
	16:00	43,96	1	1			1	1		1	1	1	
	17:00	43,95	1	1			1	1		1	1	1	
	18:00	44,39	1	1			1	1		1	1	1	
	19:00	45,02	1	1			1	1		1	1	1	
	20:00	45,56	1	1			1	1		1	1	1	
	21:00	45,91	1	1			1	1		1	1	1	
	22:00	44,66	1	1			1	1		1	1	1	
	23:00	41,39	1	1			1	1		1	1		

Επτά φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή, 5 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Παρασκευή, 5 Ιουνίου 2026	00:00	37,86	1	1			1	1		1		1	
	01:00	34,91	1	1			1	1		1		1	
	02:00	33,01	1	1			1	1		1		1	
	03:00	31,88	1	1			1	1		1		1	
	04:00	31,31	1	1			1	1		1		1	
	05:00	31,53	1	1			1	1		1		1	
	06:00	33,19	1	1			1	1		1		1	
	07:00	37,09	1	1			1	1		1		1	
	08:00	41,55	1	1			1	1		1		1	
	09:00	44,61	1	1			1	1		1	1	1	
	10:00	46,47	1	1			1	1		1	1	1	
	11:00	47,10	1	1			1	1		1	1	1	
	12:00	47,62	1	1			1	1		1	1	1	
	13:00	48,31	1	1			1	1		1	1	1	
	14:00	48,02	1	1			1	1		1	1	1	
	15:00	46,97	1	1			1	1		1	1	1	
	16:00	46,40	1	1			1	1		1	1	1	
	17:00	46,25	1	1			1	1		1	1	1	
	18:00	46,70	1	1			1	1		1	1	1	
	19:00	47,15	1	1			1	1		1	1	1	
	20:00	47,60	1	1			1	1		1	1	1	
	21:00	48,02	1	1			1	1		1	1	1	
	22:00	46,06	1	1			1	1		1	1	1	
	23:00	41,86	1	1			1	1		1	1	1	

Επτά φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο, 6 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Σάββατο, 6 Ιουνίου 2026	00:00	38,38	1	1			1	1		1		1	
	01:00	35,67	1	1			1	1		1		1	
	02:00	33,79	1	1			1	1		1		1	
	03:00	32,74	1	1			1	1		1		1	
	04:00	31,99	1	1			1	1		1		1	
	05:00	31,88	1	1			1	1		1		1	
	06:00	33,39	1	1			1	1		1		1	
	07:00	37,19	1	1			1	1		1		1	
	08:00	41,50	1	1			1	1		1	1	1	
	09:00	44,13	1	1			1	1		1	1	1	
	10:00	45,37	1	1			1	1		1	1	1	
	11:00	46,09	1	1			1	1		1	1	1	
	12:00	47,20	1	1			1	1		1	1	1	
	13:00	47,70	1	1			1	1		1	1	1	
	14:00	47,62	1	1			1	1		1	1	1	
	15:00	46,68	1	1			1	1		1	1	1	
	16:00	45,94	1	1			1	1		1	1	1	
	17:00	45,83	1	1			1	1		1	1	1	
	18:00	46,68	1	1			1	1		1	1	1	
	19:00	47,29	1	1			1	1		1	1	1	
	20:00	47,60	1	1			1	1		1	1	1	
	21:00	47,85	1	1			1	1		1	1	1	1
	22:00	46,21	1	1			1	1		1	1	1	
	23:00	42,46	1	1			1	1		1	1	1	

Επτά φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Κυριακή, 7 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000
Η Ε Ρ Ε Δ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Κυριακή, 7 Ιουνίου 2026	00:00	38,31	1	1			1	1		1		1	
	01:00	35,72	1	1			1	1		1		1	
	02:00	34,19	1	1			1	1		1		1	
	03:00	33,15	1	1			1	1		1		1	
	04:00	32,22	1	1			1	1		1		1	
	05:00	31,89	1	1			1	1		1		1	
	06:00	33,00	1	1			1	1		1		1	
	07:00	36,09	1	1			1	1		1		1	
	08:00	39,83	1	1			1	1		1	1	1	
	09:00	41,75	1	1			1	1		1	1	1	
	10:00	42,74	1	1			1	1		1	1	1	
	11:00	43,59	1	1			1	1		1	1	1	
	12:00	44,97	1	1			1	1		1	1	1	
	13:00	46,03	1	1			1	1		1	1	1	
	14:00	46,13	1	1			1	1		1	1	1	
	15:00	45,32	1	1			1	1		1	1	1	
	16:00	44,38	1	1			1	1		1	1	1	
	17:00	44,39	1	1			1	1		1	1	1	
	18:00	45,17	1	1			1	1		1	1	1	
	19:00	45,61	1	1			1	1		1	1	1	
	20:00	46,18	1	1			1	1		1	1	1	
	21:00	46,13	1	1			1	1		1	1	1	
	22:00	44,70	1	1			1	1		1	1	1	
	23:00	41,59	1	1			1	1		1	1	1	

Επτά φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Δευτέρα, 8 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Δευτέρα, 8 Ιουνίου 2026	00:00	37,72	1	1			1	1		1		1	
	01:00	35,08	1	1			1	1		1		1	
	02:00	33,43	1	1			1	1		1		1	
	03:00	32,35	1	1			1	1		1		1	
	04:00	31,66	1	1			1	1		1		1	
	05:00	31,52	1	1			1	1		1		1	
	06:00	33,04	1	1			1	1		1		1	
	07:00	36,69	1	1			1	1		1		1	
	08:00	40,97	1	1			1	1		1	1	1	
	09:00	44,28	1	1			1	1		1	1	1	
	10:00	45,98	1	1			1	1		1	1	1	
	11:00	47,09	1	1			1	1		1	1	1	
	12:00	48,29	1	1			1	1		1	1	1	
	13:00	49,28	1	1			1	1		1	1	1	
	14:00	49,62	1	1			1	1		1	1	1	
	15:00	48,85	1	1			1	1		1	1	1	
	16:00	47,69	1	1			1	1		1	1	1	
	17:00	47,20	1	1			1	1		1	1	1	
	18:00	47,38	1	1			1	1		1	1	1	
	19:00	47,31	1	1			1	1		1	1	1	
	20:00	47,34	1	1			1	1		1	1	1	
	21:00	47,08	1	1			1	1		1	1	1	
	22:00	45,35	1	1			1	1		1	1	1	
	23:00	41,74	1	1			1	1		1	1	1	

Επτά φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη, 9 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000
Η Ε Ρ Ε Δ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τρίτη, 9 Ιουνίου 2026	00:00	38,94	1	1			1	1		1	1	1	
	01:00	36,07	1	1			1	1		1	1	1	
	02:00	34,33	1	1			1	1		1	1		
	03:00	33,25	1	1			1	1		1	1		
	04:00	32,61	1	1			1	1		1	1		
	05:00	32,73	1	1			1	1		1	1		
	06:00	34,29	1	1			1	1		1	1		
	07:00	37,82	1	1			1	1		1	1	1	
	08:00	42,00	1	1			1	1		1	1	1	
	09:00	44,90	1	1			1	1		1	1	1	
	10:00	46,34	1	1			1	1		1	1	1	
	11:00	47,37	1	1			1	1		1	1	1	
	12:00	48,45	1	1			1	1		1	1	1	1
	13:00	49,37	1	1			1	1		1	1	1	2
	14:00	49,39	1	1			1	1		1	1	1	2
	15:00	48,21	1	1			1	1		1	1	1	1
	16:00	47,00	1	1			1	1		1	1	1	
	17:00	46,87	1	1			1	1		1	1	1	
	18:00	47,54	1	1			1	1		1	1	1	
	19:00	48,24	1	1			1	1		1	1	1	1
	20:00	48,59	1	1			1	1		1	1	1	1
	21:00	48,44	1	1			1	1		1	1	1	1
	22:00	46,49	1	1			1	1		1	1	1	
	23:00	42,82	1	1			1	1		1	1	1	

Επτά φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Τετάρτη, 10 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500		3,500	5,800	7,453	9,234	10,150	10,150	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τετάρτη, 10 Ιουνίου 2026	00:00	40,63	1	1			1	1		1	1	1	
	01:00	37,34	1	1			1	1		1	1		
	02:00	35,34	1	1			1	1		1	1		
	03:00	34,05	1	1			1	1		1	1		
	04:00	33,27	1	1			1	1		1	1		
	05:00	33,49	1	1			1	1		1	1		
	06:00	35,40	1	1			1	1		1	1		
	07:00	39,10	1	1			1	1		1	1	1	
	08:00	43,49	1	1			1	1		1	1	1	
	09:00	46,67	1	1			1	1		1	1	1	
	10:00	48,36	1	1			1	1		1	1	1	1
	11:00	49,31	1	1			1	1		1	1	1	2
	12:00	50,18	1	1			1	1		1	1	1	3
	13:00	50,95	1	1			1	1		1	1	1	4
	14:00	50,85	1	1			1	1		1	1	1	4
	15:00	49,96	1	1			1	1		1	1	1	3
	16:00	48,85	1	1			1	1		1	1	1	2
	17:00	48,34	1	1			1	1		1	1	1	1
	18:00	48,72	1	1			1	1		1	1	1	2
	19:00	49,26	1	1			1	1		1	1	1	2
	20:00	49,63	1	1			1	1		1	1	1	3
	21:00	49,56	1	1			1	1		1	1	1	3
	22:00	47,84	1	1			1	1		1	1	1	1
	23:00	44,56	1	1			1	1		1	1	1	

Έξι φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Πέμπτη, 11 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Πέμπτη, 11 Ιουνίου 2026	00:00	40,91	1	1			1	1		1	1	1	
	01:00	37,96	1	1			1	1		1	1	1	
	02:00	35,97	1	1			1	1		1	1	1	
	03:00	34,69	1	1			1	1		1	1	1	
	04:00	34,08	1	1			1	1		1	1	1	
	05:00	34,43	1	1			1	1		1	1	1	
	06:00	36,19	1	1			1	1		1	1	1	
	07:00	39,61	1	1			1	1		1	1	1	
	08:00	43,66	1	1			1	1		1	1	1	
	09:00	47,12	1	1			1	1		1	1	1	
	10:00	49,18	1	1			1	1		1	1	1	
	11:00	49,87	1	1			1	1		1	1	1	
	12:00	50,06	1	1			1	1		1	1	1	
	13:00	50,26	1	1			1	1		1	1	1	
	14:00	50,39	1	1			1	1		1	1	1	
	15:00	49,85	1	1			1	1		1	1	1	
	16:00	49,80	1	1			1	1		1	1	1	
	17:00	49,79	1	1			1	1		1	1	1	
	18:00	49,92	1	1			1	1		1	1	1	
	19:00	50,14	1	1			1	1		1	1	1	
	20:00	49,30	1	1			1	1		1	1	1	
	21:00	49,43	1	1			1	1		1	1	1	
	22:00	48,36	1	1			1	1		1	1	1	
	23:00	45,02	1	1			1	1		1	1	1	

Έξι φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Παρασκευή, 12 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500		3,500	5,800	7,543	9,234	10,150	10,150	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Παρασκευή, 12 Ιουνίου 2026	00:00	40,05	1	1			1	1		1	1		
	01:00	37,16	1	1			1	1		1	1		
	02:00	35,30	1	1			1	1		1	1		
	03:00	34,01	1	1			1	1		1	1		
	04:00	33,34	1	1			1	1		1	1		
	05:00	33,45	1	1			1	1		1	1		
	06:00	35,08	1	1			1	1		1	1		
	07:00	38,91	1	1			1	1		1	1		1
	08:00	43,54	1	1			1	1		1	1	1	
	09:00	47,09	1	1			1	1		1	1	1	
	10:00	49,12	1	1			1	1		1	1	1	2
	11:00	50,03	1	1			1	1		1	1	1	3
	12:00	50,91	1	1			1	1		1	1	1	4
	13:00	51,32	1	1			1	1		1	1	1	5
	14:00	51,34	1	1			1	1		1	1	1	5
	15:00	50,72	1	1			1	1		1	1	1	4
	16:00	50,19	1	1			1	1		1	1	1	4
	17:00	50,01	1	1			1	1		1	1	1	3
	18:00	50,18	1	1			1	1		1	1	1	3
	19:00	50,06	1	1			1	1		1	1	1	3
	20:00	49,83	1	1			1	1		1	1	1	3
	21:00	50,11	1	1			1	1		1	1	1	3
	22:00	48,55	1	1			1	1		1	1	1	2
	23:00	44,48	1	1			1	1		1	1	1	

Έξι φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Σάββατο, 13 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,453	9,234	10,150	10,150	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Σάββατο, 13 Ιουνίου 2026	00:00	40,22	1	1			1	1	1		1	1	
	01:00	37,17	1	1			1	1	1		1	1	
	02:00	35,19	1	1			1	1	1		1		
	03:00	33,98	1	1			1	1	1		1		
	04:00	33,24	1	1			1	1	1		1		
	05:00	33,13	1	1			1	1	1		1		
	06:00	34,58	1	1			1	1	1		1		
	07:00	38,39	1	1			1	1	1		1	1	
	08:00	42,68	1	1			1	1	1		1	1	
	09:00	45,79	1	1			1	1	1		1	1	
	10:00	47,25	1	1			1	1	1		1	1	2
	11:00	48,31	1	1			1	1	1		1	1	3
	12:00	49,39	1	1			1	1	1		1	1	4
	13:00	49,84	1	1			1	1	1		1	1	5
	14:00	49,31	1	1			1	1	1		1	1	5
	15:00	48,64	1	1			1	1	1		1	1	4
	16:00	47,45	1	1			1	1	1		1	1	3
	17:00	47,22	1	1			1	1	1		1	1	3
	18:00	47,64	1	1			1	1	1		1	1	3
	19:00	48,42	1	1			1	1	1		1	1	3
	20:00	48,59	1	1			1	1	1		1	1	3
	21:00	48,66	1	1			1	1	1		1	1	3
	22:00	46,97	1	1			1	1	1		1	1	2
	23:00	43,73	1	1			1	1	1		1	1	1

Εξι φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Κυριακή, 14 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,453	9,234	10,150	10,150	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Κυριακή, 14 Ιουνίου 2026	00:00	39,62	1	1			1	1	1		1	1	
	01:00	37,15	1	1			1	1	1		1	1	
	02:00	35,53	1	1			1	1	1		1		
	03:00	34,29	1	1			1	1	1		1		
	04:00	33,37	1	1			1	1	1		1		
	05:00	33,02	1	1			1	1	1		1		
	06:00	34,17	1	1			1	1	1		1		
	07:00	37,64	1	1			1	1	1		1	1	
	08:00	41,39	1	1			1	1	1		1	1	
	09:00	43,37	1	1			1	1	1		1	1	
	10:00	44,06	1	1			1	1	1		1	1	
	11:00	44,63	1	1			1	1	1		1	1	
	12:00	45,61	1	1			1	1	1		1	1	
	13:00	46,48	1	1			1	1	1		1	1	1
	14:00	46,26	1	1			1	1	1		1	1	1
	15:00	45,15	1	1			1	1	1		1	1	
	16:00	43,92	1	1			1	1	1		1	1	
	17:00	44,06	1	1			1	1	1		1	1	
	18:00	45,02	1	1			1	1	1		1	1	
	19:00	45,89	1	1			1	1	1		1	1	
	20:00	46,63	1	1			1	1	1		1	1	1
	21:00	47,02	1	1			1	1	1		1	1	1
	22:00	45,79	1	1			1	1	1		1	1	
	23:00	42,72	1	1			1	1	1		1	1	

Εξι φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Δευτέρα, 15 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,453	9,234	10,150	10,150	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Δευτέρα, 15 Ιουνίου 2026	00:00	38,37	1	1			1	1	1		1	1	
	01:00	35,55	1	1			1	1	1		1		
	02:00	33,84	1	1			1	1	1		1		
	03:00	32,80	1	1			1	1	1		1		
	04:00	32,20	1	1			1	1	1		1		
	05:00	32,32	1	1			1	1	1		1		
	06:00	34,02	1	1			1	1	1		1		
	07:00	38,18	1	1			1	1	1		1		2
	08:00	42,40	1	1			1	1	1		1	1	1
	09:00	45,03	1	1			1	1	1		1	1	1
	10:00	46,41	1	1			1	1	1		1	1	1
	11:00	47,39	1	1			1	1	1		1	1	2
	12:00	48,53	1	1			1	1	1		1	1	3
	13:00	49,58	1	1			1	1	1		1	1	4
	14:00	49,80	1	1			1	1	1		1	1	5
	15:00	49,04	1	1			1	1	1		1	1	5
	16:00	47,90	1	1			1	1	1		1	1	4
	17:00	47,70	1	1			1	1	1		1	1	3
	18:00	48,16	1	1			1	1	1		1	1	3
	19:00	48,50	1	1			1	1	1		1	1	3
	20:00	48,77	1	1			1	1	1		1	1	4
	21:00	48,48	1	1			1	1	1		1	1	3
	22:00	46,66	1	1			1	1	1		1	1	2
	23:00	43,00	1	1			1	1	1		1	1	

Εξι φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Τρίτη, 16 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500		3,500	5,800	7,453	9,234	10,150	10,150	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τρίτη, 16 Ιουνίου 2026	00:00	39,31	1	1			1	1		1	1	1	
	01:00	36,26	1	1			1	1		1	1	1	
	02:00	34,34	1	1			1	1		1	1	1	
	03:00	33,21	1	1			1	1		1	1	1	
	04:00	32,80	1	1			1	1		1	1	1	
	05:00	33,26	1	1			1	1		1	1	1	
	06:00	35,33	1	1			1	1		1	1	1	
	07:00	39,05	1	1			1	1		1	1	1	
	08:00	43,09	1	1			1	1		1	1	1	
	09:00	45,61	1	1			1	1		1	1	1	
	10:00	46,71	1	1			1	1		1	1	1	
	11:00	47,62	1	1			1	1		1	1	1	
	12:00	48,88	1	1			1	1		1	1	1	2
	13:00	50,02	1	1			1	1		1	1	1	3
	14:00	50,18	1	1			1	1		1	1	1	3
	15:00	49,11	1	1			1	1		1	1	1	3
	16:00	47,89	1	1			1	1		1	1	1	3
	17:00	47,59	1	1			1	1		1	1	1	2
	18:00	48,50	1	1			1	1		1	1	1	2
	19:00	49,57	1	1			1	1		1	1	1	3
	20:00	49,98	1	1			1	1		1	1	1	3
	21:00	49,32	1	1			1	1		1	1	1	2
	22:00	47,43	1	1			1	1		1	1	1	
	23:00	43,78	1	1			1	1		1	1	1	

Εξι φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Τετάρτη, 17 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500		3,500	5,800	7,453	9,234	10,150	10,150	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τετάρτη, 17 Ιουνίου 2026	00:00	39,05	1	1			1	1		1	1	1	
	01:00	35,72	1	1			1	1		1	1		
	02:00	33,91	1	1			1	1		1	1		
	03:00	32,89	1	1			1	1		1	1		
	04:00	32,52	1	1			1	1		1	1		
	05:00	33,11	1	1			1	1		1	1		
	06:00	35,35	1	1			1	1		1	1		
	07:00	38,90	1	1			1	1		1	1	1	
	08:00	43,02	1	1			1	1		1	1	1	
	09:00	46,01	1	1			1	1		1	1	1	
	10:00	47,58	1	1			1	1		1	1	1	
	11:00	48,46	1	1			1	1		1	1	1	1
	12:00	49,38	1	1			1	1		1	1	1	2
	13:00	50,37	1	1			1	1		1	1	1	4
	14:00	50,59	1	1			1	1		1	1	1	4
	15:00	49,84	1	1			1	1		1	1	1	3
	16:00	48,97	1	1			1	1		1	1	1	2
	17:00	48,47	1	1			1	1		1	1	1	2
	18:00	48,75	1	1			1	1		1	1	1	2
	19:00	49,27	1	1			1	1		1	1	1	2
	20:00	49,04	1	1			1	1		1	1	1	2
	21:00	48,36	1	1			1	1		1	1	1	1
	22:00	46,64	1	1			1	1		1	1	1	1
	23:00	43,65	1	1			1	1		1	1	1	

Έξι φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Πέμπτη, 18 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500		3,500	5,800	7,453	9,234	10,150	10,150	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Πέμπτη, 18 Ιουνίου 2026	00:00	40,31	1	1			1	1		1	1	1	
	01:00	37,32	1	1			1	1		1	1		
	02:00	35,49	1	1			1	1		1	1		
	03:00	34,30	1	1			1	1		1	1		
	04:00	33,77	1	1			1	1		1	1		
	05:00	34,01	1	1			1	1		1	1		
	06:00	35,58	1	1			1	1		1	1		
	07:00	39,12	1	1			1	1		1	1	1	
	08:00	43,30	1	1			1	1		1	1	1	
	09:00	46,55	1	1			1	1		1	1	1	
	10:00	48,51	1	1			1	1		1	1	1	1
	11:00	49,49	1	1			1	1		1	1	1	3
	12:00	50,24	1	1			1	1		1	1	1	3
	13:00	50,49	1	1			1	1		1	1	1	4
	14:00	50,47	1	1			1	1		1	1	1	4
	15:00	50,22	1	1			1	1		1	1	1	3
	16:00	49,76	1	1			1	1		1	1	1	3
	17:00	49,54	1	1			1	1		1	1	1	3
	18:00	49,55	1	1			1	1		1	1	1	3
	19:00	49,54	1	1			1	1		1	1	1	3
	20:00	49,70	1	1			1	1		1	1	1	3
	21:00	50,01	1	1			1	1		1	1	1	3
	22:00	48,59	1	1			1	1		1	1	1	2
	23:00	45,05	1	1			1	1		1	1	1	1

Έξι φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Παρασκευή, 19 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500		3,500	5,800	7,453	9,234	10,150	10,150	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Παρασκευή, 19 Ιουνίου 2026	00:00	40,75	1	1			1	1		1	1	1	
	01:00	37,80	1	1			1	1		1	1		
	02:00	35,74	1	1			1	1		1	1		
	03:00	34,47	1	1			1	1		1	1		
	04:00	33,65	1	1			1	1		1	1		
	05:00	33,62	1	1			1	1		1	1		
	06:00	35,18	1	1			1	1		1	1		
	07:00	39,05	1	1			1	1		1	1	1	
	08:00	43,47	1	1			1	1		1	1	1	
	09:00	46,29	1	1			1	1		1	1	1	
	10:00	47,49	1	1			1	1		1	1	1	
	11:00	48,29	1	1			1	1		1	1	1	1
	12:00	49,37	1	1			1	1		1	1	1	2
	13:00	50,23	1	1			1	1		1	1	1	3
	14:00	50,30	1	1			1	1		1	1	1	3
	15:00	49,46	1	1			1	1		1	1	1	3
	16:00	48,74	1	1			1	1		1	1	1	2
	17:00	48,54	1	1			1	1		1	1	1	2
	18:00	48,55	1	1			1	1		1	1	1	2
	19:00	48,84	1	1			1	1		1	1	1	2
	20:00	49,29	1	1			1	1		1	1	1	2
	21:00	50,10	1	1			1	1		1	1	1	3
	22:00	48,75	1	1			1	1		1	1	1	2
	23:00	44,72	1	1			1	1		1	1	1	

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Σάββατο, 20 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500		3,500	5,800	7,453	9,234	10,150	10,150	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Σάββατο, 20 Ιουνίου 2026	00:00	41,00	1	1			1	1		1	1	1	
	01:00	38,17	1	1			1	1		1	1	1	
	02:00	36,33	1	1			1	1		1	1	1	
	03:00	35,11	1	1			1	1		1	1	1	
	04:00	34,11	1	1			1	1		1	1	1	
	05:00	33,86	1	1			1	1		1	1	1	
	06:00	35,11	1	1			1	1		1	1	1	
	07:00	38,99	1	1			1	1		1	1	1	
	08:00	43,27	1	1			1	1		1	1	1	
	09:00	46,07	1	1			1	1		1	1	1	
	10:00	47,67	1	1			1	1		1	1	1	
	11:00	48,63	1	1			1	1		1	1	1	1
	12:00	49,73	1	1			1	1		1	1	1	2
	13:00	50,31	1	1			1	1		1	1	1	3
	14:00	50,16	1	1			1	1		1	1	1	3
	15:00	49,40	1	1			1	1		1	1	1	2
	16:00	48,66	1	1			1	1		1	1	1	1
	17:00	48,59	1	1			1	1		1	1	1	1
	18:00	49,00	1	1			1	1		1	1	1	1
	19:00	49,31	1	1			1	1		1	1	1	2
	20:00	49,42	1	1			1	1		1	1	1	2
	21:00	50,11	1	1			1	1		1	1	1	3
	22:00	48,59	1	1			1	1		1	1	1	1
	23:00	45,25	1	1			1	1		1	1	1	

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Κυριακή, 21 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500		3,500	5,800	7,453	9,234	10,150	10,150	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Κυριακή, 21 Ιουνίου 2026	00:00	40,90	1	1			1	1		1	1	1	
	01:00	38,37	1	1			1	1		1	1	1	
	02:00	36,62	1	1			1	1		1	1	1	
	03:00	35,34	1	1			1	1		1	1	1	
	04:00	34,18	1	1			1	1		1	1	1	
	05:00	33,79	1	1			1	1		1	1	1	
	06:00	34,91	1	1			1	1		1	1	1	
	07:00	38,25	1	1			1	1		1	1	1	
	08:00	42,18	1	1			1	1		1	1	1	
	09:00	44,72	1	1			1	1		1	1	1	
	10:00	46,10	1	1			1	1		1	1	1	
	11:00	46,92	1	1			1	1		1	1	1	
	12:00	48,14	1	1			1	1		1	1	1	
	13:00	48,98	1	1			1	1		1	1	1	1
	14:00	48,89	1	1			1	1		1	1	1	1
	15:00	47,68	1	1			1	1		1	1	1	
	16:00	46,61	1	1			1	1		1	1	1	
	17:00	46,50	1	1			1	1		1	1	1	
	18:00	47,69	1	1			1	1		1	1	1	
	19:00	48,34	1	1			1	1		1	1	1	1
	20:00	48,61	1	1			1	1		1	1	1	1
	21:00	48,61	1	1			1	1		1	1	1	1
	22:00	47,25	1	1			1	1		1	1	1	
	23:00	44,26	1	1			1	1		1	1	1	

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Δευτέρα, 22 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,453	9,234	10,150	10,150	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Δευτέρα, 22 Ιουνίου 2026	00:00	40,48	1	1			1	1		1	1	1	
	01:00	37,62	1	1			1	1		1	1	1	
	02:00	35,94	1	1			1	1		1	1	1	
	03:00	34,89	1	1			1	1		1	1	1	
	04:00	34,00	1	1			1	1		1	1	1	
	05:00	33,76	1	1			1	1		1	1	1	
	06:00	34,96	1	1			1	1		1	1	1	
	07:00	38,93	1	1			1	1		1	1	1	
	08:00	43,53	1	1			1	1		1	1	1	
	09:00	46,91	1	1			1	1		1	1	1	
	10:00	48,66	1	1			1	1		1	1	1	1
	11:00	49,92	1	1			1	1		1	1	1	2
	12:00	51,29	1	1			1	1		1	1	1	4
	13:00	52,39	1	1			1	1		1	1	1	5
	14:00	52,68	1	1			1	1		1	1	1	5
	15:00	51,82	1	1			1	1		1	1	1	5
	16:00	50,75	1	1			1	1		1	1	1	3
	17:00	50,39	1	1			1	1		1	1	1	3
	18:00	50,84	1	1			1	1		1	1	1	3
	19:00	50,79	1	1			1	1		1	1	1	3
	20:00	50,43	1	1			1	1		1	1	1	3
	21:00	49,83	1	1			1	1		1	1	1	2
	22:00	48,15	1	1			1	1		1	1	1	
	23:00	44,45	1	1			1	1		1	1	1	

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Τρίτη, 23 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,453	9,234	10,150	10,150	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τρίτη, 23 Ιουνίου 2026	00:00	40,90	1	1			1	1		1	1	1	
	01:00	37,84	1	1			1	1		1	1	1	
	02:00	36,02	1	1			1	1		1	1	1	
	03:00	34,81	1	1			1	1		1	1	1	
	04:00	34,00	1	1			1	1		1	1	1	
	05:00	34,12	1	1			1	1		1	1	1	
	06:00	35,72	1	1			1	1		1	1	1	
	07:00	39,32	1	1			1	1		1	1	1	
	08:00	43,62	1	1			1	1		1	1	1	
	09:00	46,30	1	1			1	1		1	1	1	
	10:00	47,61	1	1			1	1		1	1	1	
	11:00	48,64	1	1			1	1		1	1	1	
	12:00	49,76	1	1			1	1		1	1	1	
	13:00	50,70	1	1			1	1		1	1	1	
	14:00	50,90	1	1			1	1		1	1	1	
	15:00	50,18	1	1			1	1		1	1	1	
	16:00	49,10	1	1			1	1		1	1	1	
	17:00	49,06	1	1			1	1		1	1	1	
	18:00	49,81	1	1			1	1		1	1	1	
	19:00	50,37	1	1			1	1		1	1	1	
	20:00	50,28	1	1			1	1		1	1	1	
	21:00	49,83	1	1			1	1		1	1	1	
	22:00	48,10	1	1			1	1		1	1	1	
	23:00	44,37	1	1			1	1		1	1	1	

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Τετάρτη, 24 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500		3,500	5,800	7,453	9,234	10,150	10,150	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τετάρτη, 24 Ιουνίου 2026	00:00	40,39	1	1			1	1		1	1	1	
	01:00	37,39	1	1			1	1		1	1	1	
	02:00	35,50	1	1			1	1		1	1	1	
	03:00	34,23	1	1			1	1		1	1	1	
	04:00	33,51	1	1			1	1		1	1	1	
	05:00	33,81	1	1			1	1		1	1	1	
	06:00	35,58	1	1			1	1		1	1	1	
	07:00	39,01	1	1			1	1		1	1	1	
	08:00	43,35	1	1			1	1		1	1	1	
	09:00	46,43	1	1			1	1		1	1	1	
	10:00	47,95	1	1			1	1		1	1	1	
	11:00	49,48	1	1			1	1		1	1	1	1
	12:00	50,55	1	1			1	1		1	1	1	3
	13:00	51,63	1	1			1	1		1	1	1	3
	14:00	52,26	1	1			1	1		1	1	1	4
	15:00	52,02	1	1			1	1		1	1	1	4
	16:00	50,73	1	1			1	1		1	1	1	3
	17:00	50,19	1	1			1	1		1	1	1	2
	18:00	50,24	1	1			1	1		1	1	1	2
	19:00	50,38	1	1			1	1		1	1	1	2
	20:00	50,49	1	1			1	1		1	1	1	2
	21:00	50,67	1	1			1	1		1	1	1	3
	22:00	49,31	1	1			1	1		1	1	1	1
	23:00	45,29	1	1			1	1		1	1	1	

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Πέμπτη, 25 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500		3,500	5,800	7,453	9,234	10,150	10,150	1,000	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x15)
Πέμπτη, 25 Ιουνίου 2026	00:00	42,35	1	1			1	1		1	1	1		
	01:00	38,88	1	1			1	1		1	1	1		
	02:00	36,95	1	1			1	1		1	1	1		
	03:00	35,71	1	1			1	1		1	1	1		
	04:00	35,03	1	1			1	1		1	1	1		
	05:00	35,26	1	1			1	1		1	1	1		
	06:00	36,98	1	1			1	1		1	1	1		
	07:00	40,66	1	1			1	1		1	1	1		
	08:00	44,71	1	1			1	1		1	1	1		
	09:00	47,77	1	1			1	1		1	1	1		
	10:00	49,92	1	1			1	1		1	1	1	1	
	11:00	50,88	1	1			1	1		1	1	1	2	
	12:00	51,28	1	1			1	1		1	1	1	2	
	13:00	51,57	1	1			1	1		1	1	1	3	
	14:00	51,72	1	1			1	1		1	1	1	3	
	15:00	51,38	1	1			1	1		1	1	1	3	
	16:00	50,99	1	1			1	1		1	1	1	3	
	17:00	50,73	1	1			1	1		1	1	1	2	
	18:00	50,79	1	1			1	1		1	1	1	2	
	19:00	50,75	1	1			1	1		1	1	1	2	
	20:00	50,54	1	1			1	1		1	1	1	2	
	21:00	50,73	1	1			1	1		1	1	1	2	
	22:00	49,36	1	1			1	1		1	1	1	2	
	23:00	46,08	1	1			1	1		1	1	1		

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Παρασκευή, 26 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500		3,500	5,800	7,453	9,234	10,150	10,150	1,000	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x15)
Παρασκευή, 26 Ιουνίου 2026	00:00	42,03	1	1	1		1	1		1	1	1		
	01:00	38,90	1		1		1	1		1	1	1		
	02:00	36,92	1		1		1	1		1	1	1		
	03:00	35,67	1		1		1	1		1	1	1		
	04:00	34,82	1		1		1	1		1	1	1		
	05:00	34,88	1		1		1	1		1	1	1		
	06:00	36,42	1		1		1	1		1	1	1		
	07:00	39,70	1		1		1	1		1	1	1		
	08:00	43,83	1	1	1		1	1		1	1	1		
	09:00	47,65	1	1	1		1	1		1	1	1		
	10:00	49,91	1	1	1		1	1		1	1	1		
	11:00	51,21	1	1	1		1	1		1	1	1		
	12:00	52,69	1	1	1		1	1		1	1	1	1	
	13:00	53,33	1	1	1		1	1		1	1	1	1	
	14:00	53,26	1	1	1		1	1		1	1	1	1	
	15:00	52,75	1	1	1		1	1		1	1	1	1	
	16:00	52,20	1	1	1		1	1		1	1	1		
	17:00	52,13	1	1	1		1	1		1	1	1		
	18:00	52,41	1	1	1		1	1		1	1	1		
	19:00	52,31	1	1	1		1	1		1	1	1		
	20:00	51,77	1	1	1		1	1		1	1	1		
	21:00	51,76	1	1	1		1	1		1	1	1		
	22:00	50,29	1	1	1		1	1		1	1	1		
	23:00	46,21	1	1	1		1	1		1	1	1		

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Σάββατο, 27 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,453	9,234	10,150	10,150	1,000	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοίκ. H/Z (x15)
Σάββατο, 27 Ιουνίου 2026	00:00	42,69	1	1			1	1		1	1	1		
	01:00	40,08	1	1			1	1		1	1	1		
	02:00	37,98	1	1			1	1		1	1	1		
	03:00	36,42	1	1			1	1		1	1	1		
	04:00	35,29	1	1			1	1		1	1	1		
	05:00	35,10	1	1			1	1		1	1	1		
	06:00	36,60	1	1			1	1		1	1	1		
	07:00	40,15	1	1			1	1		1	1	1		
	08:00	44,72	1	1	1		1	1		1	1	1		
	09:00	48,40	1	1	1		1	1		1	1	1		
	10:00	50,06	1	1	1		1	1		1	1	1		
	11:00	50,81	1	1	1		1	1		1	1	1		
	12:00	51,78	1	1	1		1	1		1	1	1	1	
	13:00	52,78	1	1	1		1	1		1	1	1	2	
	14:00	53,16	1	1	1		1	1		1	1	1	3	
	15:00	52,96	1	1	1		1	1		1	1	1	2	
	16:00	52,66	1	1	1		1	1		1	1	1	2	
	17:00	53,12	1	1	1		1	1		1	1	1	2	
	18:00	53,82	1	1	1		1	1		1	1	1	2	
	19:00	53,47	1	1	1		1	1		1	1	1	3	
	20:00	52,28	1	1	1		1	1		1	1	1	2	
	21:00	51,82	1	1	1		1	1		1	1	1	1	
	22:00	50,26	1	1	1		1	1		1	1	1		
	23:00	47,12	1	1	1		1	1		1	1	1		

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Κυριακή, 28 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,453	9,234	10,150	10,150	1,000	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοίκ. H/Z (x15)
Κυριακή, 28 Ιουνίου 2026	00:00	43,01	1	1			1	1		1	1	1		
	01:00	40,45	1	1			1	1		1	1	1		
	02:00	38,51	1	1			1	1		1	1	1		
	03:00	37,04	1	1			1	1		1	1	1		
	04:00	35,78	1	1			1	1		1	1	1		
	05:00	35,17	1	1			1	1		1	1	1		
	06:00	35,97	1	1			1	1		1	1	1		
	07:00	39,39	1	1			1	1		1	1	1		
	08:00	43,75	1	1			1	1		1	1	1		
	09:00	46,70	1	1	1		1	1		1	1	1		
	10:00	48,26	1	1	1		1	1		1	1	1		
	11:00	49,39	1	1	1		1	1		1	1	1		
	12:00	50,76	1	1	1		1	1		1	1	1		
	13:00	51,71	1	1	1		1	1		1	1	1		
	14:00	51,79	1	1	1		1	1		1	1	1		
	15:00	51,02	1	1	1		1	1		1	1	1		
	16:00	50,17	1	1	1		1	1		1	1	1		
	17:00	50,37	1	1	1		1	1		1	1	1		
	18:00	51,18	1	1	1		1	1		1	1	1		
	19:00	51,51	1	1	1		1	1		1	1	1		
	20:00	50,80	1	1	1		1	1		1	1	1		
	21:00	50,54	1	1	1		1	1		1	1	1		
	22:00	49,18	1	1	1		1	1		1	1	1		
	23:00	46,01	1	1	1		1	1		1	1	1		

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Δευτέρα, 29 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			7,200	7,200	3,500	3,500	3,500	5,800	7,453	9,234	10,150	10,150	1,000	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοίκ. H/Z (x15)
Δευτέρα, 29 Ιουνίου 2026	00:00	42,01	1	1			1	1		1	1	1		
	01:00	39,12	1	1			1	1		1	1	1		
	02:00	37,34	1	1			1	1		1	1	1		
	03:00	36,19	1	1			1	1		1	1	1		
	04:00	35,07	1	1			1	1		1	1	1		
	05:00	34,93	1	1			1	1		1	1	1		
	06:00	36,18	1	1			1	1		1	1	1		
	07:00	39,24	1	1			1	1		1	1	1		
	08:00	43,84	1	1			1	1		1	1	1		
	09:00	48,09	1	1			1	1		1	1	1		
	10:00	50,10	1	1	1		1	1		1	1	1		
	11:00	52,96	1	1	1		1	1		1	1	1	2	
	12:00	54,42	1	1	1		1	1		1	1	1	4	
	13:00	55,33	1	1	1		1	1		1	1	1	4	
	14:00	55,62	1	1	1		1	1		1	1	1	4	
	15:00	55,11	1	1	1		1	1		1	1	1	4	
	16:00	54,05	1	1	1		1	1		1	1	1	3	
	17:00	53,81	1	1	1		1	1		1	1	1	3	
	18:00	54,00	1	1	1		1	1		1	1	1	3	
	19:00	53,61	1	1	1		1	1		1	1	1	3	
	20:00	52,54	1	1	1		1	1		1	1	1	3	
	21:00	51,82	1	1	1		1	1		1	1	1	1	
	22:00	50,10	1	1	1		1	1		1	1	1		
	23:00	46,38	1	1	1		1	1		1	1	1		

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Τρίτη, 30 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500		3,500	5,800	7,453	9,234	10,150	10,150	1,000	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x15)
Τρίτη, 30 Ιουνίου 2026	00:00	43,71	1	1	1		1	1		1	1	1		
	01:00	40,45	1	1			1	1		1	1	1		
	02:00	38,47	1	1			1	1		1	1	1		
	03:00	37,16	1	1			1	1		1	1	1		
	04:00	36,23	1	1			1	1		1	1	1		
	05:00	36,30	1	1			1	1		1	1	1		
	06:00	37,90	1	1			1	1		1	1	1		
	07:00	41,05	1	1			1	1		1	1	1		
	08:00	45,08	1	1	1		1	1		1	1	1		
	09:00	49,44	1	1	1		1	1		1	1	1		
	10:00	51,18	1	1	1		1	1		1	1	1		
	11:00	52,77	1	1	1		1	1		1	1	1	1	
	12:00	54,27	1	1	1		1	1		1	1	1	3	
	13:00	55,42	1	1	1		1	1		1	1	1	4	
	14:00	55,66	1	1	1		1	1		1	1	1	5	
	15:00	54,80	1	1	1		1	1		1	1	1	3	
	16:00	53,52	1	1	1		1	1		1	1	1	2	
	17:00	53,37	1	1	1		1	1		1	1	1	2	
	18:00	53,99	1	1	1		1	1		1	1	1	3	
	19:00	54,02	1	1	1		1	1		1	1	1	3	
	20:00	53,51	1	1	1		1	1		1	1	1	2	
	21:00	52,74	1	1	1		1	1		1	1	1	2	
	22:00	51,36	1	1	1		1	1		1	1	1		
	23:00	48,20	1	1	1		1	1		1	1	1		

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης