

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 3 Σεπτεμβρίου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 3 Σεπτεμβρίου 2026	00:00	2,322		1	1			1	
	01:00	2,149		1	1			1	
	02:00	2,018		1	1			1	
	03:00	1,940		1	1			1	
	04:00	1,905		1	1			1	
	05:00	1,987		1		1		1	
	06:00	2,031		1		1		1	
	07:00	2,151		1		1		1	
	08:00	2,361				1	1	1	
	09:00	2,441				1	1	1	
	10:00	2,453				1	1	1	
	11:00	2,530				1	1	1	
	12:00	2,674				1	1	1	
	13:00	2,722				1	1	1	
	14:00	2,667				1	1	1	
	15:00	2,571				1	1	1	
	16:00	2,492				1	1	1	
	17:00	2,512				1	1	1	
	18:00	2,789				1	1	1	
	19:00	2,922			1	1	1	1	
	20:00	3,024			1	1	1	1	
	21:00	2,875			1	1	1	1	
	22:00	2,638			1		1	1	
	23:00	2,417			1		1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης


Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 4 Σεπτεμβρίου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 4 Σεπτεμβρίου 2026	00:00	2,182			1		1	1	
	01:00	2,017			1		1	1	
	02:00	1,927			1		1	1	
	03:00	1,866			1		1	1	
	04:00	1,812			1		1		
	05:00	1,802			1		1		
	06:00	1,902			1		1		
	07:00	2,038			1		1	1	
	08:00	2,206			1		1	1	
	09:00	2,335			1	1		1	
	10:00	2,446			1	1		1	
	11:00	2,431			1	1		1	
	12:00	2,411			1	1		1	
	13:00	2,552			1	1		1	
	14:00	2,552			1	1		1	
	15:00	2,471			1	1		1	
	16:00	2,423			1	1		1	
	17:00	2,515			1	1		1	
	18:00	2,634			1	1		1	
	19:00	2,829			1	1	1	1	
	20:00	2,985			1	1	1	1	
	21:00	2,800			1	1	1	1	
	22:00	2,520			1		1	1	
	23:00	2,347			1		1	1	


Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 5 Σεπτεμβρίου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900
Η Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 5 Σεπτεμβρίου 2026	00:00	2,199			1		1	1	
	01:00	2,042			1		1	1	
	02:00	1,943			1		1	1	
	03:00	1,858			1		1	1	
	04:00	1,808			1		1		
	05:00	1,772			1		1		
	06:00	1,822			1		1		
	07:00	2,023			1	1	1		
	08:00	2,253			1	1	1		
	09:00	2,275			1	1	1		
	10:00	2,337			1	1	1		
	11:00	2,336			1	1	1		
	12:00	2,460			1	1	1		
	13:00	2,596			1	1	1		
	14:00	2,560			1	1	1		
	15:00	2,438			1	1	1		
	16:00	2,423			1	1	1		
	17:00	2,495			1	1	1		
	18:00	2,620			1	1	1		
	19:00	2,756		1	1	1	1		
	20:00	2,861		1	1	1	1		
	21:00	2,738		1	1	1	1		
	22:00	2,478		1	1		1		
	23:00	2,305		1	1		1		




Μη διαθεσιμότητα μονάδας λόγω συντήρησης




Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 6 Σεπτεμβρίου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 6 Σεπτεμβρίου 2026	00:00	2,102		1	1		1		
	01:00	1,951		1	1		1		
	02:00	1,835		1	1		1		
	03:00	1,738			1		1		
	04:00	1,697			1		1		
	05:00	1,747			1		1		
	06:00	1,814			1		1		
	07:00	1,895			1		1		
	08:00	2,151			1		1	1	
	09:00	2,306			1		1	1	
	10:00	2,420			1		1	1	
	11:00	2,470			1		1	1	
	12:00	2,596			1		1	1	
	13:00	2,637			1		1	1	
	14:00	2,517			1		1	1	
	15:00	2,432			1		1	1	
	16:00	2,436			1		1	1	
	17:00	2,538			1		1	1	
	18:00	2,711			1		1	1	
	19:00	2,867			1	1	1	1	
	20:00	2,949			1	1	1	1	
	21:00	2,801			1	1	1	1	
	22:00	2,566			1	1		1	
	23:00	2,448			1	1		1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης



Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 7 Σεπτεμβρίου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 7 Σεπτεμβρίου 2026	00:00	2,306			1	1		1	
	01:00	2,131			1	1		1	
	02:00	2,052			1	1		1	
	03:00	1,987			1	1		1	
	04:00	1,906			1	1		1	
	05:00	1,887			1	1		1	
	06:00	1,966			1			1	
	07:00	2,060	1		1			1	
	08:00	2,265	1		1			1	
	09:00	2,322	1		1			1	
	10:00	2,353	1		1			1	
	11:00	2,381	1		1			1	
	12:00	2,477	1		1			1	
	13:00	2,524	1		1			1	
	14:00	2,394	1		1			1	
	15:00	2,351	1		1			1	
	16:00	2,221	1		1			1	
	17:00	2,251	1		1			1	
	18:00	2,430	1		1			1	
	19:00	2,638	1		1			1	
	20:00	2,790	1		1			1	
	21:00	2,676			1		1	1	
	22:00	2,453			1		1	1	
	23:00	2,248			1		1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 8 Σεπτεμβρίου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 8 Σεπτεμβρίου 2026	00:00	2,042			1		1	1	
	01:00	1,859			1		1	1	
	02:00	1,773			1		1		
	03:00	1,706			1		1		
	04:00	1,666			1		1		
	05:00	1,663			1		1		
	06:00	1,745			1		1		
	07:00	1,884	1		1		1		
	08:00	2,073	1		1		1		
	09:00	2,081	1		1		1		
	10:00	2,031	1		1		1		
	11:00	2,022	1		1		1		
	12:00	2,111	1		1		1		
	13:00	2,186	1		1		1		
	14:00	2,143	1		1		1		
	15:00	2,029	1		1		1		
	16:00	1,991	1		1		1		
	17:00	2,088	1		1		1		
	18:00	2,310	1		1		1		
	19:00	2,493	1		1		1		
	20:00	2,658	1		1		1		
	21:00	2,596	1		1		1		
	22:00	2,305		1	1		1		
	23:00	2,051		1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 9 Σεπτεμβρίου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 9 Σεπτεμβρίου 2026	00:00	1,918		1	1		1		
	01:00	1,759			1		1		
	02:00	1,686			1		1		
	03:00	1,654			1		1		
	04:00	1,626			1		1		
	05:00	1,699			1		1		
	06:00	1,759			1		1		
	07:00	1,840			1		1		
	08:00	2,017	1		1		1		
	09:00	2,099	1		1		1		
	10:00	2,104	1		1		1		
	11:00	2,122	1		1		1		
	12:00	2,170	1		1		1		
	13:00	2,224	1		1		1		
	14:00	2,047	1		1		1		
	15:00	1,946	1		1		1		
	16:00	1,874	1		1		1		
	17:00	2,045	1		1		1		
	18:00	2,299	1		1		1		
	19:00	2,495	1		1		1		
	20:00	2,639			1	1	1		
	21:00	2,499			1	1	1		
	22:00	2,264			1	1	1		
	23:00	2,022			1	1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης