

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Παρασκευή, 25 Σεπτεμβρίου 2026			
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900
Η Ε Ρ Ε Δ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 25 Σεπτεμβρίου 2026	00:00	1,386		1	1				
	01:00	1,310		1	1				
	02:00	1,270		1	1				
	03:00	1,261		1	1				
	04:00	1,274		1	1				
	05:00	1,316		1	1				
	06:00	1,396		1	1				
	07:00	1,498		1	1				
	08:00	1,551		1	1				
	09:00	1,601		1	1				
	10:00	1,575		1	1				
	11:00	1,538		1	1				
	12:00	1,498		1	1				
	13:00	1,507		1	1				
	14:00	1,433		1	1				
	15:00	1,323		1	1				
	16:00	1,307		1	1				
	17:00	1,424		1	1				
	18:00	1,630		1	1				
	19:00	1,833	1	1	1				
	20:00	1,913	1	1	1				
	21:00	1,840	1	1	1				
	22:00	1,683	1	1	1				
	23:00	1,521	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Σάββατο, 26 Σεπτεμβρίου 2026			
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 26 Σεπτεμβρίου 2026	00:00	1,413	1	1					
	01:00	1,326	1	1					
	02:00	1,277	1	1					
	03:00	1,257	1	1					
	04:00	1,251	1	1					
	05:00	1,263	1	1					
	06:00	1,318	1	1					
	07:00	1,415	1	1					
	08:00	1,497	1	1					
	09:00	1,571	1	1					
	10:00	1,559	1	1					
	11:00	1,525	1	1					
	12:00	1,494	1	1					
	13:00	1,498	1	1					
	14:00	1,451	1	1					
	15:00	1,379	1	1					
	16:00	1,367	1	1					
	17:00	1,495	1	1					
	18:00	1,654	1	1			1		
	19:00	1,850	1	1			1		
	20:00	1,901	1	1			1		
	21:00	1,805	1	1			1		
	22:00	1,644		1			1		
	23:00	1,507		1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Κυριακή, 27 Σεπτεμβρίου 2026			
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 27 Σεπτεμβρίου 2026	00:00	1,384		1			1		
	01:00	1,298		1			1		
	02:00	1,249		1			1		
	03:00	1,227		1			1		
	04:00	1,222		1			1		
	05:00	1,231		1			1		
	06:00	1,271		1			1		
	07:00	1,358		1			1		
	08:00	1,463		1			1		
	09:00	1,547		1			1		
	10:00	1,602		1			1		
	11:00	1,629		1			1		
	12:00	1,601		1			1		
	13:00	1,517		1			1		
	14:00	1,390		1			1		
	15:00	1,268		1			1		
	16:00	1,227		1			1		
	17:00	1,317		1			1		
	18:00	1,515		1			1		
	19:00	1,735	1	1			1		
	20:00	1,800	1	1			1		
	21:00	1,730	1	1			1		
	22:00	1,607		1			1		
	23:00	1,487		1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Δευτέρα, 28 Σεπτεμβρίου 2026			
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 28 Σεπτεμβρίου 2026	00:00	1,309		1			1		
	01:00	1,218		1			1		
	02:00	1,178		1			1		
	03:00	1,169		1			1		
	04:00	1,169		1			1		
	05:00	1,183		1			1		
	06:00	1,236		1			1		
	07:00	1,346		1			1		
	08:00	1,487		1			1		
	09:00	1,565		1			1		
	10:00	1,575		1			1		
	11:00	1,537		1			1		
	12:00	1,513		1			1		
	13:00	1,488		1			1		
	14:00	1,393		1			1		
	15:00	1,270		1			1		
	16:00	1,243		1			1		
	17:00	1,329		1			1		
	18:00	1,533		1			1		
	19:00	1,748		1	1		1		
	20:00	1,808		1	1		1		
	21:00	1,741		1	1		1		
	22:00	1,596			1		1		
	23:00	1,424			1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Τρίτη, 29 Σεπτεμβρίου 2026			
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 29 Σεπτεμβρίου 2026	00:00	1,280			1		1		
	01:00	1,196			1		1		
	02:00	1,169			1		1		
	03:00	1,167			1		1		
	04:00	1,164			1		1		
	05:00	1,182			1		1		
	06:00	1,241			1		1		
	07:00	1,365			1		1		
	08:00	1,506			1		1		
	09:00	1,577			1		1		
	10:00	1,573			1		1		
	11:00	1,532			1		1		
	12:00	1,494			1		1		
	13:00	1,465			1		1		
	14:00	1,368			1		1		
	15:00	1,253			1		1		
	16:00	1,236			1		1		
	17:00	1,333			1		1		
	18:00	1,530			1		1		
	19:00	1,765		1	1		1		
	20:00	1,825		1	1		1		
	21:00	1,762		1	1		1		
	22:00	1,617			1		1		
	23:00	1,439			1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Τετάρτη, 30 Σεπτεμβρίου 2026			
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 30 Σεπτεμβρίου 2026	00:00	1,287			1		1		
	01:00	1,204			1		1		
	02:00	1,165			1		1		
	03:00	1,152			1		1		
	04:00	1,150			1		1		
	05:00	1,169			1		1		
	06:00	1,236			1		1		
	07:00	1,353			1		1		
	08:00	1,464			1		1		
	09:00	1,492			1		1		
	10:00	1,472			1		1		
	11:00	1,462			1		1		
	12:00	1,467			1		1		
	13:00	1,465			1		1		
	14:00	1,351			1		1		
	15:00	1,252			1		1		
	16:00	1,233			1		1		
	17:00	1,318			1		1		
	18:00	1,493			1		1		
	19:00	1,717	1		1		1		
	20:00	1,809	1		1		1		
	21:00	1,748	1		1		1		
	22:00	1,594			1		1		
	23:00	1,413			1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Πέμπτη, 1 Οκτωβρίου 2026			
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 1 Οκτωβρίου 2026	00:00	1,227			1		1		
	01:00	1,159			1		1		
	02:00	1,131			1		1		
	03:00	1,123			1		1		
	04:00	1,133			1		1		
	05:00	1,172			1		1		
	06:00	1,253			1		1		
	07:00	1,367			1		1		
	08:00	1,451			1		1		
	09:00	1,446			1		1		
	10:00	1,418			1		1		
	11:00	1,409			1		1		
	12:00	1,428			1		1		
	13:00	1,429			1		1		
	14:00	1,300			1		1		
	15:00	1,180			1		1		
	16:00	1,158			1		1		
	17:00	1,285			1		1		
	18:00	1,543			1		1		
	19:00	1,725	1		1		1		
	20:00	1,775	1		1		1		
	21:00	1,678			1		1		
	22:00	1,505			1		1		
	23:00	1,336			1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης