

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 25 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 25 Αυγούστου 2026	00:00	2,932	1			1				1	1
	01:00	2,724	1			1				1	1
	02:00	2,573	1			1				1	1
	03:00	2,468	1			1				1	1
	04:00	2,374	1			1					1
	05:00	2,317	1			1					1
	06:00	2,273	1			1					1
	07:00	2,434	1			1					1
	08:00	2,779	1			1				1	1
	09:00	3,048	1			1				1	1
	10:00	3,099	1			1				1	1
	11:00	3,260	1			1				1	1
	12:00	3,419	1			1		1		1	1
	13:00	3,563	1			1		1		1	1
	14:00	3,625	1			1		1		1	1
	15:00	3,484	1			1		1		1	1
	16:00	3,405	1			1		1		1	1
	17:00	3,432	1			1		1		1	1
	18:00	3,480	1			1		1		1	1
	19:00	3,647	1			1		1		1	1
	20:00	3,767	1			1		1		1	1
	21:00	3,535	1			1		1		1	1
	22:00	3,317	1			1		1		1	1
	23:00	3,161	1						1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 26 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 26 Αυγούστου 2026	00:00	3,035	1			1				1	1
	01:00	2,837	1			1				1	1
	02:00	2,676	1			1				1	1
	03:00	2,600	1			1				1	1
	04:00	2,538	1			1					1
	05:00	2,513	1			1					1
	06:00	2,422	1			1					1
	07:00	2,542	1			1					1
	08:00	2,901	1			1		1			1
	09:00	3,133	1			1				1	1
	10:00	3,296	1			1				1	1
	11:00	3,404	1			1		1		1	1
	12:00	3,546	1			1		1		1	1
	13:00	3,642	1			1		1		1	1
	14:00	3,680	1			1		1		1	1
	15:00	3,650	1			1		1		1	1
	16:00	3,558	1			1		1		1	1
	17:00	3,512	1			1		1		1	1
	18:00	3,613	1			1		1		1	1
	19:00	3,708	1			1		1		1	1
	20:00	3,692	1			1		1		1	1
	21:00	3,312	1			1		1		1	1
	22:00	2,992	1			1				1	1
	23:00	2,886	1			1				1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 27 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ρ Α Σ Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 27 Αυγούστου 2026	00:00	2,682	1			1				1	1
	01:00	2,469	1			1				1	1
	02:00	2,334	1			1					1
	03:00	2,246	1			1					1
	04:00	2,170				1		1			1
	05:00	2,079				1		1			1
	06:00	2,030				1		1			1
	07:00	2,213				1				1	1
	08:00	2,622				1		1		1	1
	09:00	2,998	1			1				1	1
	10:00	3,084	1			1				1	1
	11:00	3,218	1			1				1	1
	12:00	3,404	1			1		1		1	1
	13:00	3,664	1			1		1		1	1
	14:00	3,735	1			1		1		1	1
	15:00	3,622	1			1		1		1	1
	16:00	3,552	1			1		1		1	1
	17:00	3,675	1			1		1		1	1
	18:00	3,778	1			1		1		1	1
	19:00	3,779	1			1		1		1	1
	20:00	3,800	1			1		1		1	1
	21:00	3,650	1			1		1		1	1
	22:00	3,619	1			1		1		1	1
	23:00	3,496	1			1		1		1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 28 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ρ Ε Τ Ε Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 28 Αυγούστου 2026	00:00	3,304	1			1		1		1	1
	01:00	3,110	1			1		1		1	1
	02:00	2,922	1			1				1	1
	03:00	2,864	1			1				1	1
	04:00	2,774	1			1				1	1
	05:00	2,722	1			1				1	1
	06:00	2,648	1			1				1	1
	07:00	2,775	1			1				1	1
	08:00	3,012	1			1				1	1
	09:00	3,203	1			1				1	1
	10:00	3,261	1			1				1	1
	11:00	3,341	1			1		1		1	1
	12:00	3,342	1			1		1		1	1
	13:00	3,375	1			1		1		1	1
	14:00	3,389	1			1		1		1	1
	15:00	3,350	1			1		1		1	1
	16:00	3,287	1			1		1		1	1
	17:00	3,260	1			1		1		1	1
	18:00	3,333	1			1		1		1	1
	19:00	3,368	1			1		1		1	1
	20:00	3,401	1			1		1		1	1
	21:00	3,291	1			1		1		1	1
	22:00	3,175	1			1				1	1
	23:00	3,061	1			1				1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 29 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 29 Αυγούστου 2026	00:00	2,865	1			1				1	1
	01:00	2,684	1			1			1	1	
	02:00	2,515	1			1			1	1	
	03:00	2,387	1			1					1
	04:00	2,276	1			1					1
	05:00	2,224	1			1					1
	06:00	2,129	1			1					1
	07:00	2,193	1			1					1
	08:00	2,499	1			1					1
	09:00	2,598	1			1				1	1
	10:00	2,633	1			1				1	1
	11:00	2,769	1			1				1	1
	12:00	2,944	1			1				1	1
	13:00	3,034	1			1				1	1
	14:00	3,069	1			1				1	1
	15:00	2,987	1			1				1	1
	16:00	2,916	1			1				1	1
	17:00	2,962	1			1				1	1
	18:00	3,102	1			1				1	1
	19:00	3,149	1			1				1	1
	20:00	3,171	1			1				1	1
	21:00	3,026	1			1				1	1
	22:00	2,861	1			1				1	1
	23:00	2,395	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 30 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 30 Αυγούστου 2026	00:00	2,233	1			1					1
	01:00	2,061	1			1					1
	02:00	1,972	1			1					1
	03:00	1,911	1			1					1
	04:00	1,856	1			1					1
	05:00	1,807	1			1					1
	06:00	1,781	1			1					1
	07:00	1,943	1			1					1
	08:00	2,398	1			1					1
	09:00	2,631	1			1				1	1
	10:00	2,710	1			1				1	1
	11:00	2,912	1			1				1	1
	12:00	3,039	1			1				1	1
	13:00	3,095	1			1				1	1
	14:00	3,058	1			1				1	1
	15:00	2,914	1			1				1	1
	16:00	2,780	1			1				1	1
	17:00	2,879	1			1				1	1
	18:00	2,999	1			1				1	1
	19:00	3,034	1			1				1	1
	20:00	3,095	1			1				1	1
	21:00	2,931	1			1				1	1
	22:00	2,854	1			1				1	1
	23:00	2,786	1			1				1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 31 Αυγούστου 2026						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	1,000	1,000	0,900	1,000
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 31 Αυγούστου 2026	00:00	2,686	1			1				1	1
	01:00	2,578	1			1					1
	02:00	2,441	1			1					1
	03:00	2,364	1			1					1
	04:00	2,316	1			1					1
	05:00	2,254	1			1					1
	06:00	2,197	1			1					1
	07:00	2,316	1			1					1
	08:00	2,577	1			1				1	1
	09:00	2,758	1			1				1	1
	10:00	2,849	1			1				1	1
	11:00	2,980	1			1				1	1
	12:00	3,141	1			1				1	1
	13:00	3,241	1			1				1	1
	14:00	3,280	1			1				1	1
	15:00	3,132	1			1				1	1
	16:00	3,050	1			1				1	1
	17:00	3,063	1			1				1	1
	18:00	3,170	1			1				1	1
	19:00	3,236	1			1				1	1
	20:00	3,296	1			1				1	1
	21:00	3,158	1			1				1	1
	22:00	2,967	1			1				1	1
	23:00	2,818	1			1				1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης