

M
L
K
J
I
H
G
F
E
D
C
B
A
EN

VA TECH T&D GmbH
A-1411 VIEANA AUSTRIA
NOTE PROTECTION DIN 341



M2

M1

AXIS NO° 2

M3

AXIS NO° 1

M4

FOUNDATION EQUIPMENT	
a	CIRCUIT BREAKER
b	DISCONNECTOR WITH EARTHING SWITCH
c	CURRENT TRANSFORMER
d	VOLTAGE TRANSFORMER
e	COUPLING CAPACITOR AND LINE TRAP
f	INJECTION TRANSFORMER AND SURGE ARRESTER
g	AUXILIARY TRANSFORMER
h	CABLE RACK
k	NEUTRAL GROUNDING RESISTOR
m	POWER TRANSFORMER
n	LINE GANTRY
o	BUSBAR GANTRY
p	LIGHTNING TOWER
q	CABLE PULLING PIT
s	SURGE ARRESTER
t	CAPACITOR BANK

ASSOCIATED DRAWINGS	
35025-2007	FOUNDATION DETAILS DRAWING
35025-2009	TYPICAL CABLE DUCTS DRAWING

- MAIN SWITCHYARD FENCE
- SECONDARY SWITCHYARD FENCE
- WOODEN FENCE
- TRANSFORMER RAIL
- CABLE CONDUIT $\geq \varnothing 200\text{mm}$
- CABLE CONDUIT $\geq \varnothing 100\text{mm}$

- Αρμοδιότητας ΑΔΜΗΕ
- Αρμοδιότητας ΔΕΔΔΗΕ
- Κοινής Αρμοδιότητας

PPC Drawing Nr.: FF-10834-120	
Purchaser: PUBLIC POWER CORPORATION S.A.	Proj. Nr: C243 35 025
Plant: LARISSA – AGIA SUBSTATION	Customer Nr:
Title: FOUNDATION DRAWING	=AEAD0
150kV SWITCHYARD	+AEAD0
TOP VIEW	DYPM – 99204
Drawn: 23/03/2005 Katschke	Scale: 1:200
Checked: 23/03/2005 KEK	Note Protection DIN 34-1
Approved: 23/03/2005 PA	Revised: 15/11/08 [Name: PSM]
ISO / R 158 EUROPA	
Drawing Nr: 35025-2005	
Sheet: 1 of 1	

E	Τεχνολογική Σύνταξη: ΑΔΜΗΕ	25/04/2005	Z.M	A.L	
D	Προσθετο ΜΕ Νο2	11/04/2005	Z.M	A.L	
C	As Built	13/11/2006	B.A	H	AE-PH4
B	Capacitor Bank added	22/05/2006	H	H	AE-PH4
A	General Update	09/09/2005	Kerschner	KEK	PA
Mod	Modification	Date	Drawn	Checked	Approved

VA TECH T&D GmbH

Projects