

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	###				
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,900	0,900	0,900
Η Ε Ρ Ε Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G7	G8	G9
Τετάρτη, 23 Σεπτεμβρίου 2026	00:00	1,260	1			1	
	01:00	1,181	1			1	
	02:00	1,123	1			1	
	03:00	1,113	1			1	
	04:00	1,101	1			1	
	05:00	1,138	1			1	
	06:00	1,257	1			1	
	07:00	1,278	1			1	
	08:00	1,378	1			1	
	09:00	1,349	1			1	
	10:00	1,403	1			1	
	11:00	1,459	1			1	
	12:00	1,414			1	1	
	13:00	1,472			1	1	
	14:00	1,418			1	1	
	15:00	1,338			1	1	
	16:00	1,369			1	1	
	17:00	1,415			1	1	
	18:00	1,528			1	1	1
	19:00	1,665			1	1	1
	20:00	1,642			1	1	1
	21:00	1,557			1	1	1
	22:00	1,454			1	1	1
	23:00	1,284			1	1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / πρ

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	###				
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,900	0,900	0,900
Η Ρ Α Σ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G7	G8	G9
Πέμπτη, 24 Σεπτεμβρίου 2026	00:00	1,198			1	1	
	01:00	1,111			1	1	
	02:00	1,056			1	1	
	03:00	1,020			1	1	
	04:00	1,021			1	1	
	05:00	1,049			1	1	
	06:00	1,191			1	1	
	07:00	1,169			1	1	
	08:00	1,299			1	1	
	09:00	1,263			1	1	
	10:00	1,339			1	1	1
	11:00	1,419			1		1
	12:00	1,424			1		1
	13:00	1,444			1		1
	14:00	1,431			1		1
	15:00	1,340			1		1
	16:00	1,343			1		1
	17:00	1,367			1		1
	18:00	1,481			1		1
	19:00	1,580	1		1		1
	20:00	1,622	1		1		1
	21:00	1,523	1		1		1
	22:00	1,434	1		1		1
	23:00	1,273			1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / πρ

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	###				
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,900	0,900	0,900
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G7	G8	G9
Παρασκευή, 25 Σεπτεμβρίου 2026	00:00	1,221			1		1
	01:00	1,102			1		1
	02:00	1,077			1		1
	03:00	1,034			1		1
	04:00	1,043			1		1
	05:00	1,084			1		1
	06:00	1,226			1		1
	07:00	1,208			1		1
	08:00	1,278			1		1
	09:00	1,288			1		1
	10:00	1,298			1		1
	11:00	1,345			1		1
	12:00	1,378			1		1
	13:00	1,386			1		1
	14:00	1,412			1		1
	15:00	1,313			1		1
	16:00	1,341			1		1
	17:00	1,418			1		1
	18:00	1,476			1		1
	19:00	1,591			1		1
	20:00	1,631			1		1
	21:00	1,529			1		1
	22:00	1,448			1		1
	23:00	1,303			1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / πρ

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	###				
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,900	0,900	0,900
Η Ρ Α Κ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G7	G8	G9
Σάββατο, 26 Σεπτεμβρίου 2026	00:00	1,213			1		1
	01:00	1,119			1		1
	02:00	1,068			1		1
	03:00	1,041			1		1
	04:00	1,058			1		1
	05:00	1,065			1		1
	06:00	1,195			1		1
	07:00	1,191			1		1
	08:00	1,284			1		1
	09:00	1,303			1		1
	10:00	1,388			1		1
	11:00	1,532			1		1
	12:00	1,595			1		1
	13:00	1,635	1		1		1
	14:00	1,593	1		1		1
	15:00	1,494	1		1		1
	16:00	1,532	1		1		1
	17:00	1,511	1		1		1
	18:00	1,563	1		1		1
	19:00	1,667	1		1		1
	20:00	1,651	1		1		1
	21:00	1,548	1		1		1
	22:00	1,478			1		1
	23:00	1,362			1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / πρ

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	###				
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,900	0,900	0,900
Η Ε Ρ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G7	G8	G9
Κυριακή, 27 Σεπτεμβρίου 2026	00:00	1,288			1		1
	01:00	1,169			1		1
	02:00	1,116			1		1
	03:00	1,081			1		1
	04:00	1,080			1		1
	05:00	1,076			1		1
	06:00	1,184			1		1
	07:00	1,234			1		1
	08:00	1,318			1		1
	09:00	1,365			1		1
	10:00	1,489			1		1
	11:00	1,687	1		1		1
	12:00	1,721	1		1		1
	13:00	1,674	1		1		1
	14:00	1,609	1		1		1
	15:00	1,492	1		1		1
	16:00	1,452			1		1
	17:00	1,418			1		1
	18:00	1,496			1		1
	19:00	1,595			1		1
	20:00	1,545			1		1
	21:00	1,466			1		1
	22:00	1,393			1		1
	23:00	1,269			1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / πρ

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	###				
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,900	0,900	0,900
Η Ρ Α Κ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G7	G8	G9
Δευτέρα, 28 Σεπτεμβρίου 2026	00:00	1,174			1		1
	01:00	1,083			1		1
	02:00	1,024			1		1
	03:00	1,027			1		1
	04:00	1,042			1		1
	05:00	1,042			1		1
	06:00	1,198			1		1
	07:00	1,161			1		1
	08:00	1,273			1		1
	09:00	1,290			1		1
	10:00	1,259			1		1
	11:00	1,254			1		1
	12:00	1,265			1		1
	13:00	1,263			1		1
	14:00	1,241			1		1
	15:00	1,192			1		1
	16:00	1,247			1		1
	17:00	1,266			1		1
	18:00	1,330			1		1
	19:00	1,472			1		1
	20:00	1,498			1		1
	21:00	1,408			1		1
	22:00	1,330			1		1
	23:00	1,178			1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / πρ

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	###				
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,900	0,900	0,900
Η Ρ Α Π Ε Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G7	G8	G9
Τρίτη, 29 Σεπτεμβρίου 2026	00:00	1,132			1		1
	01:00	1,039			1		1
	02:00	0,998			1		1
	03:00	0,986			1		1
	04:00	0,995			1		1
	05:00	1,018			1		1
	06:00	1,127			1		1
	07:00	1,136			1		1
	08:00	1,169			1		1
	09:00	1,223			1		1
	10:00	1,197			1		1
	11:00	1,199			1		1
	12:00	1,212			1		1
	13:00	1,198			1		1
	14:00	1,184			1		1
	15:00	1,107			1		1
	16:00	1,217			1		1
	17:00	1,194			1		1
	18:00	1,290			1		1
	19:00	1,423			1		1
	20:00	1,417			1		1
	21:00	1,334			1		1
	22:00	1,268			1		1
	23:00	1,119			1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / πρ